

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P751998

Luminaire Tested: LD4D65D010-EU4DR6555659030-4LBCSSQMMS

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P751998
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D65D010-EU4DR6555659030-4LBCSSQMMS
Description: 4 INCH SQAURE SHALLOW CAST MATTE METALLIC SILVER TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5855.6 lumens
Efficiency: N/A
Efficacy: 80.4 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct

Input Watts (W): 72.8
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P751998
CATALOG NUMBER: LD4D65D010-EU4DR6555659030-4LBCSSQMMS

Luminous Intensity Polar Plot





TEST NUMBER: P751998

CATALOG NUMBER: LD4D65D010-EU4DR6555659030-4LBCSSQMMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93		
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85		
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78		
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72		
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66		
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61		
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56		
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52		
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49		
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	310516
5°	309732
10°	309470
15°	299932
20°	273047
25°	237944
30°	197906
35°	156813
40°	113180
45°	71503
50°	37271
55°	19805
60°	10408
65°	5721
70°	2408
75°	2640
80°	1850
85°	1541

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 71503 cd/sqm



TEST NUMBER: P751998

CATALOG NUMBER: LD4D65D010-EU4DR6555659030-4LBCSSQMMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	502.8	8.6
10°-20°	1376.8	23.5
20°-30°	1683.0	28.7
30°-40°	1365.5	23.3
40°-50°	680.5	11.6
50°-60°	189.8	3.2
60°-70°	43.1	0.7
70°-80°	11.2	0.2
80°-90°	2.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3562.6	60.8
0°-40°	4928.1	84.2
0°-60°	5798.4	99.0
0°-90°	5855.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5855.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5317	
5°	5283	503
15°	4960	1377
25°	3692	1683
35°	2199	1366
45°	866	680
55°	194	190
65°	41	43
75°	12	11
85°	2	3
90°	0	



TEST NUMBER: P751998

CATALOG NUMBER: LD4D65D010-EU4DR6555659030-4LBCSSQMMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	5316.7
2.5°	5312.8
5°	5283.1
7.5°	5265.9
10°	5218.3
12.5°	5121.4
15°	4960.5
17.5°	4708.9
20°	4393.2
22.5°	4052.6
25°	3692.4
27.5°	3307.2
30°	2934.6
32.5°	2566.6
35°	2199.4
37.5°	1832.9
40°	1484.5
42.5°	1157.9
45°	865.7
47.5°	603.2
50°	410.2
52.5°	282.8
55°	194.5
57.5°	131.3
60°	89.1
62.5°	61.7
65°	41.4
67.5°	21.1
70°	14.1
72.5°	13.3
75°	11.7
77.5°	7.8
80°	5.5
82.5°	3.9
85°	2.3
87.5°	1.6
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)