

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P740964

Luminaire Tested: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P740964
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2310-195-36)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D08D010-EU4DR200210IC9030-4LBSQW1B
Description: 4 INCH SQAURE DEEP 45° CUTOFF SPECULAR BLACK TRIM, WITH 20° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 633.2 lumens
Efficiency: N/A
Efficacy: 71.1 lumens/watt
Spacing Criteria (0/90/45): 0.34 / 0.34 / 0.36
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 8.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P740964

CATALOG NUMBER: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

Luminous Intensity Polar Plot





TEST NUMBER: P740964
 CATALOG NUMBER: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	115	113	111	109	113	111	109	108	107	106	104	103	102	101	100	99	98	97	97	98	97																
2	111	108	105	102	109	106	104	101	103	101	99	100	99	97	98	96	95	94	94	98	94																
3	108	103	100	97	106	102	99	96	100	97	95	97	95	93	95	93	92	91	91	95	91																
4	105	99	96	93	103	98	95	92	96	93	91	95	92	90	93	91	89	88	88	93	89																
5	102	96	92	89	100	95	91	89	94	90	88	92	89	87	91	88	86	85	85	91	88																
6	99	93	89	86	98	92	88	86	91	87	85	90	87	84	88	86	84	83	83	88	86																
7	96	90	86	83	95	89	86	83	88	85	82	87	84	82	86	84	82	81	81	86	84																
8	94	87	83	81	93	87	83	80	86	83	80	85	82	80	84	82	80	79	79	84	82																
9	91	85	81	78	91	85	81	78	84	80	78	83	80	78	82	80	78	77	77	82	80																
10	89	83	79	76	88	82	79	76	82	78	76	81	78	76	81	78	76	75	75	81	78																

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	393754
5°	355236
10°	199382
15°	101351
20°	42905
25°	19807
30°	10484
35°	5655
40°	3024
45°	1792
50°	1037
55°	552
60°	350
65°	259
70°	96
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 1792 cd/sqm



TEST NUMBER: P740964

CATALOG NUMBER: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	256.6	40.5
10°-20°	252.7	39.9
20°-30°	82.5	13.0
30°-40°	28.1	4.4
40°-50°	9.5	1.5
50°-60°	2.8	0.4
60°-70°	0.9	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	591.8	93.5
0°-40°	619.9	97.9
0°-60°	632.2	99.8
0°-90°	633.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	633.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3604	
5°	3239	257
15°	896	253
25°	164	83
35°	42	28
45°	12	9
55°	3	3
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P740964

CATALOG NUMBER: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	3603.8
0.5°	3603.8
1°	3599.3
1.5°	3590.3
2°	3573.9
2.5°	3552.1
3°	3521.3
3.5°	3478.3
4°	3414.5
4.5°	3336.8
5°	3238.9
5.5°	3110.2
6°	2978.3
6.5°	2827.2
7°	2679.3
7.5°	2506.0
8°	2351.3
8.5°	2195.7
9°	2051.9
9.5°	1920.0
10°	1797.1
12.5°	1290.4
15°	896.0
17.5°	585.3
20°	369.0
22.5°	239.1
25°	164.3
27.5°	115.5
30°	83.1
32.5°	59.7
35°	42.4
37.5°	29.5
40°	21.2
42.5°	15.4
45°	11.6
47.5°	9.0
50°	6.1
52.5°	3.9
55°	2.9
57.5°	2.2
60°	1.6
62.5°	1.3
65°	1.0



TEST NUMBER: P740964
CATALOG NUMBER: LD4D08D010-EU4DR200210IC9030-4LBSQW1B

CANDELA DISTRIBUTION (continued):

	0°
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





67.5°		0.6
70°		0.3

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)