

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P755884

Luminaire Tested: LD4D90BD010-EU4DR6570959027-4LBCSSQMB

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P755884
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D90BD010-EU4DR6570959027-4LBCSSQMB
Description: 4 INCH SQAURE SHALLOW CAST MATTE BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7341.5 lumens
Efficiency: N/A
Efficacy: 74.2 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct


Input Watts (W): 98.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P755884

CATALOG NUMBER: LD4D90BD010-EU4DR6570959027-4LBCSSQMB

Luminous Intensity Polar Plot





TEST NUMBER: P755884

CATALOG NUMBER: LD4D90BD010-EU4DR6570959027-4LBCSSQMB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93																			
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85																			
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78																			
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72																			
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66																			
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61																			
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56																			
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52																			
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49																			
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	389309
5°	388327
10°	387996
15°	376039
20°	342334
25°	298326
30°	248121
35°	196597
40°	141892
45°	89641
50°	46729
55°	24835
60°	13047
65°	7172
70°	3005
75°	3317
80°	2321
85°	1943

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 89641 cd/sqm



TEST NUMBER: P755884

CATALOG NUMBER: LD4D90BD010-EU4DR6570959027-4LBCSSQMB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	630.4	8.6
10°-20°	1726.2	23.5
20°-30°	2110.0	28.7
30°-40°	1712.0	23.3
40°-50°	853.1	11.6
50°-60°	238.0	3.2
60°-70°	54.1	0.7
70°-80°	14.1	0.2
80°-90°	3.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4466.6	60.8
0°-40°	6178.6	84.2
0°-60°	7269.7	99.0
0°-90°	7341.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7341.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6666	
5°	6624	630
15°	6219	1726
25°	4629	2110
35°	2757	1712
45°	1085	853
55°	244	238
65°	52	54
75°	15	14
85°	3	4
90°	0	



TEST NUMBER: P755884

CATALOG NUMBER: LD4D90BD010-EU4DR6570959027-4LBCSSQMB

CANDELA DISTRIBUTION (FULL):

	0°
0°	6665.8
2.5°	6660.9
5°	6623.7
7.5°	6602.2
10°	6542.4
12.5°	6421.0
15°	6219.2
17.5°	5903.7
20°	5508.0
22.5°	5080.9
25°	4629.4
27.5°	4146.4
30°	3679.2
32.5°	3217.8
35°	2757.4
37.5°	2298.0
40°	1861.1
42.5°	1451.7
45°	1085.3
47.5°	756.2
50°	514.3
52.5°	354.6
55°	243.9
57.5°	164.6
60°	111.7
62.5°	77.4
65°	51.9
67.5°	26.4
70°	17.6
72.5°	16.7
75°	14.7
77.5°	9.8
80°	6.9
82.5°	4.9
85°	2.9
87.5°	2.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)