

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P755976

Luminaire Tested: LD4D90BD010-EU4DR7070959030-4LBCSSQMMS

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P755976
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-76)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD4D90BD010-EU4DR7070959030-4LBCSSQMMMS
Description: 4 INCH SQAURE SHALLOW CAST MATTE METALLIC SILVER TRIM, WITH 70° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 8533.3 lumens
Efficiency: N/A
Efficacy: 86.3 lumens/watt
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.04
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct


Input Watts (W): 98.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P755976

CATALOG NUMBER: LD4D90BD010-EU4DR7070959030-4LBCSSQMMS

Luminous Intensity Polar Plot





TEST NUMBER: P755976

CATALOG NUMBER: LD4D90BD010-EU4DR7070959030-4LBCSSQMMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20																	
RC	80									50									30									10									0								
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0															
RCR																																													
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																											
1	113	110	107	105	111	108	106	103	104	102	100	100	99	97	97	95	94	93																											
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85																											
3	101	94	88	84	99	92	87	83	90	85	82	87	84	81	85	82	79	78																											
4	95	87	81	76	93	86	80	76	83	78	75	81	77	74	79	76	73	71																											
5	89	80	74	69	88	79	73	69	78	72	68	76	71	68	74	70	67	65																											
6	84	75	68	63	83	74	68	63	72	67	63	71	66	62	69	65	62	60																											
7	80	69	63	58	78	69	62	58	67	62	58	66	61	57	65	61	57	56																											
8	75	65	58	54	74	64	58	54	63	57	53	62	57	53	61	56	53	51																											
9	71	61	54	50	70	60	54	50	59	53	50	58	53	49	57	53	49	48																											
10	67	57	50	46	66	56	50	46	55	50	46	55	50	46	54	49	46	44																											

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	735893
5°	734054
10°	732467
15°	732262
20°	725101
25°	681141
30°	607237
35°	484153
40°	321488
45°	192205
50°	99642
55°	52366
60°	18531
65°	310
70°	0
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 192205 cd/sqm



TEST NUMBER: P755976

CATALOG NUMBER: LD4D90BD010-EU4DR7070959030-4LBCSSQMMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	636.5	7.5
10°-20°	1825.4	21.4
20°-30°	2575.2	30.2
30°-40°	2223.0	26.1
40°-50°	995.5	11.7
50°-60°	260.6	3.1
60°-70°	17.0	0.2
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5037.1	59.0
0°-40°	7260.2	85.1
0°-60°	8516.3	99.8
0°-90°	8533.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8533.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6735	
5°	6693	636
15°	6474	1825
25°	5650	2575
35°	3630	2223
45°	1244	996
55°	275	261
65°	1	17
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P755976

CATALOG NUMBER: LD4D90BD010-EU4DR7070959030-4LBCSSQMMS

CANDELA DISTRIBUTION (FULL):

0°	
0°	6735.2
2.5°	6728.0
5°	6692.8
7.5°	6663.8
10°	6602.0
12.5°	6546.3
15°	6473.6
17.5°	6390.0
20°	6236.2
22.5°	5983.1
25°	5650.0
27.5°	5263.7
30°	4813.1
32.5°	4262.0
35°	3629.8
37.5°	2932.2
40°	2254.0
42.5°	1712.6
45°	1243.9
47.5°	857.5
50°	586.2
52.5°	404.5
55°	274.9
57.5°	165.9
60°	84.8
62.5°	26.6
65°	1.2
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)