

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P206303

Luminaire Tested: **LD4B10D010 EU4B10208035 4LBCSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P206303
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD4B10D010 EU4B10208035 4LBCSMW1
Description: PORTFOLIO 4 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH CAST MATTE WHITE TRIM
WATTAGE D010TR-10.05W DE010-10.58W D5LT-10.2W DMX-10.6W DL2-11.8W
DL3-11.1W DLE-11.39W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1148.1 lumens
Efficiency: N/A
Efficacy: 116.0 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P206303

CATALOG NUMBER: LD4B10D010 EU4B10208035 4LBCSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P206303

CATALOG NUMBER: LD4B10D010 EU4B10208035 4LBCSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	110	106	102	99	108	104	100	97	100	97	94	96	93	91	92	90	89	87																			
2	101	94	87	82	99	92	86	81	88	84	79	85	81	78	82	79	76	74																			
3	93	83	75	70	90	81	74	69	79	73	68	76	71	67	73	69	65	63																			
4	85	74	66	60	83	73	65	59	70	64	58	68	62	58	66	61	57	55																			
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48																			
6	73	60	52	45	71	59	51	45	57	50	45	56	49	44	54	49	44	42																			
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	50	44	39	37																			
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	33																			
9	59	46	38	33	57	45	38	32	44	37	32	43	37	32	42	36	32	30																			
10	55	42	35	30	54	42	34	30	41	34	29	40	34	29	39	33	29	27																			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P206303

CATALOG NUMBER: LD4B10D010 EU4B10208035 4LBCSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	44.4	3.9
10°-20°	126.5	11.0
20°-30°	190.3	16.6
30°-40°	225.5	19.6
40°-50°	224.4	19.5
50°-60°	180.9	15.8
60°-70°	109.4	9.5
70°-80°	40.7	3.5
80°-90°	6.1	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	361.2	31.5
0°-40°	586.7	51.1
0°-60°	992.0	86.4
0°-90°	1148.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1148.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	469	
5°	467	44
15°	448	126
25°	413	190
35°	361	226
45°	292	224
55°	202	181
65°	110	109
75°	37	41
85°	5	6
90°	0	



TEST NUMBER: P206303

CATALOG NUMBER: LD4B10D010 EU4B10208035 4LBCSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	468.9
2.5°	468.9
5°	466.8
7.5°	465.4
10°	461.3
12.5°	454.3
15°	448.0
17.5°	441.1
20°	432.7
22.5°	424.4
25°	413.2
27.5°	401.4
30°	388.2
32.5°	375.7
35°	361.1
37.5°	345.8
40°	327.7
42.5°	310.3
45°	292.2
47.5°	272.0
50°	249.8
52.5°	226.8
55°	201.8
57.5°	179.5
60°	154.4
62.5°	132.2
65°	109.9
67.5°	89.1
70°	69.6
72.5°	52.2
75°	36.9
77.5°	23.7
80°	13.9
82.5°	8.3
85°	4.9
87.5°	2.1
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)