

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P208364

Luminaire Tested: **LD4B10D010 EU4B10209040 4LBSLI1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P208364  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD4B10D010 EU4B10209040 4LBSLI1  
Description: PORTFOLIO 4 INCH SHALLOW RECESSED DOWNLIGHT  
SHALLOW DISTRIBUTION WITH SPECULAR CLEAR TRIM  
WATTAGE D010TR-10.05W DE010-10.58W D5LT-10.2W DMX-10.6W DL2-11.8W  
DL3-11.1W DLE-11.39W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 954.1 lumens  
Efficiency: N/A  
Efficacy: 96.4 lumens/watt  
Spacing Criteria (0/90/45): 0.91 / 0.91 / 1  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 9.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P208364

CATALOG NUMBER: LD4B10D010 EU4B10209040 4LBSLI1

### Luminous Intensity Polar Plot





TEST NUMBER: P208364

CATALOG NUMBER: LD4B10D010 EU4B10209040 4LBSLI1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	112	108	105	102	109	106	103	101	102	100	98	98	96	95	95	93	92	90	90	90	90
2	104	98	93	88	102	96	91	87	93	89	85	90	86	84	87	84	82	80	80	80	80
3	97	89	82	77	95	87	81	77	84	79	75	82	78	74	79	76	73	71	71	71	71
4	90	81	73	68	88	79	73	68	77	71	67	75	70	66	73	69	65	63	63	63	63
5	84	73	66	61	82	72	65	60	70	64	60	69	63	59	67	62	59	57	57	57	57
6	79	67	60	54	77	66	59	54	65	58	54	63	58	53	62	57	53	51	51	51	51
7	74	62	54	49	72	61	54	49	60	53	49	58	53	48	57	52	48	46	46	46	46
8	69	57	50	45	68	57	50	45	55	49	45	54	49	44	53	48	44	42	42	42	42
9	65	53	46	41	64	53	46	41	52	45	41	51	45	41	50	44	41	39	39	39	39
10	61	50	43	38	60	49	42	38	48	42	38	47	42	38	46	41	37	36	36	36	36

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P208364

CATALOG NUMBER: LD4B10D010 EU4B10209040 4LBSLI1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	61.8	6.5
10°-20°	157.5	16.5
20°-30°	204.1	21.4
30°-40°	200.0	21.0
40°-50°	169.5	17.8
50°-60°	111.2	11.7
60°-70°	44.7	4.7
70°-80°	5.1	0.5
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	423.4	44.4
0°-40°	623.5	65.3
0°-60°	904.1	94.8
0°-90°	954.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	954.1	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	681	
5°	663	62
15°	562	158
25°	446	204
35°	318	200
45°	221	170
55°	124	111
65°	43	45
75°	2	5
85°	0	0
90°	0	



TEST NUMBER: P208364

CATALOG NUMBER: LD4B10D010 EU4B10209040 4LBSL11

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	681.2
2.5°	675.9
5°	663.3
7.5°	642.1
10°	615.7
12.5°	587.2
15°	561.9
17.5°	534.4
20°	506.9
22.5°	477.4
25°	445.7
27.5°	413.0
30°	379.2
32.5°	347.5
35°	317.9
37.5°	293.6
40°	267.2
42.5°	244.0
45°	220.7
47.5°	196.4
50°	172.2
52.5°	147.9
55°	123.6
57.5°	101.4
60°	80.3
62.5°	61.3
65°	43.3
67.5°	28.5
70°	16.9
72.5°	7.4
75°	2.1
77.5°	1.1
80°	1.1
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)