

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P207085

Luminaire Tested: **LD4B40D010 EU4B30509727 4LBWMW1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P207085  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD4B40D010 EU4B30509727 4LBWMW1  
Description: PORTFOLIO 4 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT  
WIDE DISTRIBUTION WITH MATTE WHITE TRIM  
WATTAGE D010TR-43.02W DE010-42.54W D5LT-42.539W DMX-41.87W DL2-41.57W  
DL3-44.71W DLE-39.33W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2549.4 lumens  
Efficiency: N/A  
Efficacy: 61.0 lumens/watt  
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.09  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P207085

CATALOG NUMBER: LD4B40D010 EU4B30509727 4LBWMW1

### Luminous Intensity Polar Plot





TEST NUMBER: P207085

CATALOG NUMBER: LD4B40D010 EU4B30509727 4LBWMW1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	111	107	104	101	108	105	102	99	101	98	96	97	95	93	93	92	90	88			
2	103	96	91	86	101	94	89	85	91	87	83	88	84	81	85	82	80	78			
3	96	87	80	75	93	85	79	74	83	77	73	80	76	72	78	74	71	69			
4	89	79	72	66	87	78	71	66	75	69	65	73	68	64	71	67	63	61			
5	83	72	64	59	81	71	64	58	69	63	58	67	62	57	65	61	57	55			
6	78	66	58	53	76	65	58	53	64	57	52	62	56	52	60	55	51	50			
7	73	61	53	48	71	60	53	48	59	52	47	57	51	47	56	51	47	45			
8	68	56	49	44	67	56	49	44	54	48	43	53	47	43	52	47	43	41			
9	64	52	45	40	63	52	45	40	51	44	40	50	44	40	49	43	39	38			
10	61	49	42	37	59	48	41	37	47	41	37	46	41	37	46	40	36	35			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P207085

CATALOG NUMBER: LD4B40D010 EU4B30509727 4LBWMW1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	145.1	5.7
10°-20°	405.6	15.9
20°-30°	573.3	22.5
30°-40°	555.3	21.8
40°-50°	374.7	14.7
50°-60°	232.6	9.1
60°-70°	155.4	6.1
70°-80°	85.0	3.3
80°-90°	22.5	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1123.9	44.1
0°-40°	1679.2	65.9
0°-60°	2286.5	89.7
0°-90°	2549.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2549.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1545	
5°	1532	145
15°	1439	406
25°	1257	573
35°	893	555
45°	480	375
55°	255	233
65°	156	155
75°	79	85
85°	20	22
90°	0	



TEST NUMBER: P207085

CATALOG NUMBER: LD4B40D010 EU4B30509727 4LBMMW1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1544.9
2.5°	1544.9
5°	1531.7
7.5°	1515.1
10°	1495.3
12.5°	1475.4
15°	1439.0
17.5°	1409.3
20°	1359.6
22.5°	1310.0
25°	1257.1
27.5°	1184.3
30°	1104.9
32.5°	1002.4
35°	893.2
37.5°	784.0
40°	674.9
42.5°	565.7
45°	479.7
47.5°	400.3
50°	340.7
52.5°	291.1
55°	254.7
57.5°	225.0
60°	201.8
62.5°	178.6
65°	155.5
67.5°	135.6
70°	115.8
72.5°	99.2
75°	79.4
77.5°	62.9
80°	46.3
82.5°	33.1
85°	19.8
87.5°	6.6
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)