

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P207076

Luminaire Tested: **LD4B40D010 EU4B30508035 4LBWMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P207076
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD4B40D010 EU4B30508035 4LBWMW1
Description: PORTFOLIO 4 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-43.02W DE010-42.54W D5LT-42.539W DMX-41.87W DL2-41.57W
DL3-44.71W DLE-39.33W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3658.2 lumens
Efficiency: N/A
Efficacy: 87.5 lumens/watt
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.09
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 41.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P207076

CATALOG NUMBER: LD4B40D010 EU4B30508035 4LBWMW1

Luminous Intensity Polar Plot





TEST NUMBER: P207076

CATALOG NUMBER: LD4B40D010 EU4B30508035 4LBWMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	107	104	101	108	105	102	99	101	98	96	97	95	93	93	92	90	88																			
2	103	96	91	86	101	94	89	85	91	87	83	88	84	81	85	82	80	78																			
3	96	87	80	75	93	85	79	74	83	77	73	80	76	72	78	74	71	69																			
4	89	79	72	66	87	78	71	66	75	69	65	73	68	64	71	67	63	61																			
5	83	72	64	59	81	71	64	58	69	63	58	67	62	57	65	61	57	55																			
6	78	66	58	53	76	65	58	53	64	57	52	62	56	52	60	55	51	50																			
7	73	61	53	48	71	60	53	48	59	52	47	57	51	47	56	51	47	45																			
8	68	56	49	44	67	56	49	44	54	48	43	53	47	43	52	47	43	41																			
9	64	52	45	40	63	52	45	40	51	44	40	50	44	40	49	43	39	38																			
10	61	49	42	37	59	48	41	37	47	41	37	46	41	37	46	40	36	35																			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P207076

CATALOG NUMBER: LD4B40D010 EU4B30508035 4LBWMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	208.1	5.7
10°-20°	582.0	15.9
20°-30°	822.6	22.5
30°-40°	796.8	21.8
40°-50°	537.6	14.7
50°-60°	333.7	9.1
60°-70°	223.0	6.1
70°-80°	122.0	3.3
80°-90°	32.3	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1612.8	44.1
0°-40°	2409.6	65.9
0°-60°	3280.9	89.7
0°-90°	3658.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3658.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2217	
5°	2198	208
15°	2065	582
25°	1804	823
35°	1282	797
45°	688	538
55°	366	334
65°	223	223
75°	114	122
85°	28	32
90°	0	



TEST NUMBER: P207076

CATALOG NUMBER: LD4B40D010 EU4B30508035 4LBMMW1

CANDELA DISTRIBUTION (FULL):

0°	
0°	2216.8
2.5°	2216.8
5°	2197.8
7.5°	2174.1
10°	2145.6
12.5°	2117.1
15°	2064.9
17.5°	2022.2
20°	1951.0
22.5°	1879.8
25°	1803.8
27.5°	1699.4
30°	1585.5
32.5°	1438.3
35°	1281.7
37.5°	1125.0
40°	968.4
42.5°	811.7
45°	688.3
47.5°	574.4
50°	488.9
52.5°	417.7
55°	365.5
57.5°	322.8
60°	289.6
62.5°	256.3
65°	223.1
67.5°	194.6
70°	166.1
72.5°	142.4
75°	113.9
77.5°	90.2
80°	66.5
82.5°	47.5
85°	28.5
87.5°	9.5
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)