

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P208519

Luminaire Tested: **LD4B40D010 EU4B30509040 4LBNWH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P208519  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD4B40D010 EU4B30509040 4LBNWH1  
Description: PORTFOLIO 4 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT  
NARROW DISTRIBUTION WITH WHEAT TRIM  
WATTAGE D010TR-43.02W DE010-42.54W D5LT-42.539W DMX-41.87W DL2-41.57W  
DL3-44.71W DLE-39.33W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2329.2 lumens  
Efficiency: N/A  
Efficacy: 55.7 lumens/watt  
Spacing Criteria (0/90/45): 0.53 / 0.53 / 0.62  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P208519

CATALOG NUMBER: LD4B40D010 EU4B30509040 4LBNWH1

### Luminous Intensity Polar Plot





TEST NUMBER: P208519

CATALOG NUMBER: LD4B40D010 EU4B30509040 4LBNWH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	109	107	112	109	107	105	105	104	102	102	100	99	98	97	96	95			
2	109	105	101	98	107	103	100	97	100	97	95	97	95	93	94	92	91	89			
3	104	98	94	90	102	97	93	90	94	91	88	92	89	87	90	87	85	84			
4	100	93	88	84	98	92	87	83	90	86	82	88	84	82	86	83	81	79			
5	95	88	82	78	94	87	82	78	85	81	77	83	80	77	82	79	76	75			
6	91	83	78	74	90	82	77	74	81	76	73	79	76	73	78	75	72	71			
7	87	79	73	70	86	78	73	69	77	72	69	76	72	69	75	71	68	67			
8	84	75	70	66	82	74	69	66	73	69	65	72	68	65	71	68	65	64			
9	80	71	66	62	79	71	66	62	70	65	62	69	65	62	68	65	62	61			
10	77	68	63	59	76	68	63	59	67	62	59	66	62	59	66	62	59	58			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P208519

CATALOG NUMBER: LD4B40D010 EU4B30509040 4LBNWH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	404.8	17.4
10°-20°	759.4	32.6
20°-30°	681.3	29.3
30°-40°	390.9	16.8
40°-50°	78.0	3.3
50°-60°	9.9	0.4
60°-70°	4.5	0.2
70°-80°	0.5	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1845.5	79.2
0°-40°	2236.4	96.0
0°-60°	2324.2	99.8
0°-90°	2329.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2329.2	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	4950	
5°	4552	405
15°	2726	759
25°	1472	681
35°	619	391
45°	84	78
55°	12	10
65°	4	4
75°	0	1
85°	0	0
90°	0	



TEST NUMBER: P208519

CATALOG NUMBER: LD4B40D010 EU4B30509040 4LBNWH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	4950.2
2.5°	4849.7
5°	4552.1
7.5°	4117.8
10°	3643.3
12.5°	3176.8
15°	2726.4
17.5°	2332.3
20°	1994.6
22.5°	1713.1
25°	1471.8
27.5°	1278.8
30°	1065.6
32.5°	848.5
35°	619.3
37.5°	422.2
40°	261.4
42.5°	156.8
45°	84.4
47.5°	36.2
50°	16.1
52.5°	12.1
55°	12.1
57.5°	8.0
60°	8.0
62.5°	4.0
65°	4.0
67.5°	4.0
70°	4.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)