

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P207407

Luminaire Tested: **LD4B50D010TE EU4B30509727 4LBMGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P207407
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD4B50D010TE EU4B30509727 4LBMGPH1
Description: PORTFOLIO 4 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH GRAPHITE HAZE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2005.0 lumens
Efficiency: N/A
Efficacy: 34.1 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.92
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P207407

CATALOG NUMBER: LD4B50D010TE EU4B30509727 4LBMGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P207407

CATALOG NUMBER: LD4B50D010TE EU4B30509727 4LBMGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	110	108	105	111	108	106	104	104	102	101	100	99	98	97	96	95	93			
2	107	102	98	94	105	100	97	93	97	94	91	94	92	89	91	89	88	86			
3	102	95	90	85	100	93	89	85	91	87	83	88	85	82	86	83	81	79			
4	96	88	82	78	94	87	82	78	85	80	77	83	79	76	81	78	75	73			
5	91	82	76	72	89	81	76	71	79	74	71	78	73	70	76	72	69	68			
6	86	77	71	66	85	76	70	66	74	69	65	73	68	65	72	68	64	63			
7	82	72	66	61	80	71	65	61	70	65	61	69	64	60	68	63	60	59			
8	77	67	61	57	76	67	61	57	66	60	57	65	60	56	64	59	56	55			
9	73	63	57	53	72	63	57	53	62	57	53	61	56	53	60	56	52	51			
10	70	60	54	50	69	59	54	50	59	53	50	58	53	49	57	52	49	48			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P207407

CATALOG NUMBER: LD4B50D010TE EU4B30509727 4LBMGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	189.7	9.5
10°-20°	494.6	24.7
20°-30°	634.4	31.6
30°-40°	458.6	22.9
40°-50°	164.4	8.2
50°-60°	44.4	2.2
60°-70°	14.5	0.7
70°-80°	4.4	0.2
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1318.7	65.8
0°-40°	1777.2	88.6
0°-60°	1986.0	99.1
0°-90°	2005.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2005.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2061	
5°	2023	190
15°	1762	495
25°	1400	634
35°	734	459
45°	198	164
55°	46	44
65°	13	14
75°	4	4
85°	0	0
90°	0	



TEST NUMBER: P207407

CATALOG NUMBER: LD4B50D010TE EU4B30509727 4LBMGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2061.3
2.5°	2052.9
5°	2023.3
7.5°	1977.0
10°	1913.8
12.5°	1842.1
15°	1762.0
17.5°	1681.9
20°	1601.8
22.5°	1509.1
25°	1399.5
27.5°	1273.0
30°	1112.8
32.5°	927.4
35°	733.5
37.5°	556.4
40°	404.7
42.5°	286.6
45°	198.1
47.5°	134.9
50°	88.5
52.5°	63.2
55°	46.4
57.5°	33.7
60°	25.3
62.5°	21.1
65°	12.6
67.5°	8.4
70°	8.4
72.5°	4.2
75°	4.2
77.5°	4.2
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)