

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P208318

Luminaire Tested: **LD4B50D010TE EU4B30508030 4LBNI1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P208318  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD4B50D010TE EU4B30508030 4LBNI1  
Description: PORTFOLIO 4 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT  
NARROW DISTRIBUTION WITH SPECULAR CLEAR TRIM  
SINGLE DRIVER D010TE  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3827.3 lumens  
Efficiency: N/A  
Efficacy: 65.1 lumens/watt  
Spacing Criteria (0/90/45): 0.48 / 0.48 / 0.54  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 58.77  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P208318

CATALOG NUMBER: LD4B50D010TE EU4B30508030 4LBNLI1

### Luminous Intensity Polar Plot





TEST NUMBER: P208318

CATALOG NUMBER: LD4B50D010TE EU4B30508030 4LBNLI1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95			95
2	109	105	102	99	107	103	100	98	100	98	95	97	95	93	95	93	92	90			90
3	105	99	95	92	103	98	94	91	95	92	89	93	90	88	91	89	87	85			85
4	101	94	89	86	99	93	88	85	91	87	84	89	86	83	87	84	82	81			81
5	96	89	84	80	95	88	84	80	87	82	79	85	81	79	83	80	78	77			77
6	92	85	80	76	91	84	79	76	83	78	75	81	78	75	80	77	74	73			73
7	89	81	76	72	88	80	75	72	79	75	71	78	74	71	77	73	71	69			69
8	85	77	72	68	84	77	72	68	76	71	68	75	71	68	74	70	67	66			66
9	82	74	69	65	81	73	68	65	72	68	65	72	68	65	71	67	64	63			63
10	79	71	66	62	78	70	65	62	69	65	62	69	65	62	68	64	62	61			61

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P208318

CATALOG NUMBER: LD4B50D010TE EU4B30508030 4LBNLI1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	776.2	20.3
10°-20°	1328.8	34.7
20°-30°	1056.1	27.6
30°-40°	559.0	14.6
40°-50°	96.3	2.5
50°-60°	7.2	0.2
60°-70°	3.6	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3161.1	82.6
0°-40°	3720.1	97.2
0°-60°	3823.7	99.9
0°-90°	3827.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3827.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	9849	
5°	8830	776
15°	4804	1329
25°	2275	1056
35°	884	559
45°	100	96
55°	6	7
65°	6	4
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P208318

CATALOG NUMBER: LD4B50D010TE EU4B30508030 4LBNL11

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	9849.2
2.5°	9595.8
5°	8829.5
7.5°	7827.5
10°	6766.6
12.5°	5741.0
15°	4803.8
17.5°	3931.4
20°	3235.9
22.5°	2705.4
25°	2275.2
27.5°	1927.4
30°	1579.7
32.5°	1226.0
35°	884.1
37.5°	583.5
40°	347.8
42.5°	200.4
45°	100.2
47.5°	35.4
50°	11.8
52.5°	11.8
55°	5.9
57.5°	5.9
60°	5.9
62.5°	5.9
65°	5.9
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)