

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P840028

Luminaire Tested: **LDS4C40D010 EU4409040 4LBPSMB**

Issue Date: 8/24/2022



**Test Information**

Test Method: LM-79-08  
Report Number: P840028  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2105-247-18)  
Test Lab: INNOVATION CENTER  
Issue Date: 8/24/2022  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LDS4C40D010 EU4409040 4LBPSMB  
Description: 4 INCH 4000 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 4000K, 90CRI LEDS  
AND 4LBPS TRIM WITH MB FINISH  
Light Source: -  
Ballast/Driver: -

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 3207.9 lumens  
Efficiency: N/A  
Efficacy: 68.3 lumens/watt  
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.25  
Luminous Opening: Circular (Dia: 0.33' x H: 0')  
CIE Type: Direct

Input Watts (W): 47  
Input Voltage (V):  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P840028

CATALOG NUMBER: LDS4C40D010 EU4409040 4LBPSMB

### Luminous Intensity Polar Plot





TEST NUMBER: P840028

CATALOG NUMBER: LDS4C40D010 EU4409040 4LBPSMB

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	112	108	105	102	109	106	103	100	102	99	97	98	96	94	94	93	92	90	90	90	90
2	104	97	92	88	101	96	91	87	92	88	85	89	86	83	86	83	81	79	79	79	79
3	96	88	81	76	94	86	80	75	83	78	74	81	76	73	78	75	72	70	70	70	70
4	89	79	72	66	87	78	71	66	76	70	65	73	68	64	71	67	63	62	62	62	62
5	83	72	64	59	81	71	64	58	69	63	58	67	61	57	65	60	57	55	55	55	55
6	77	66	58	52	75	65	57	52	63	56	52	61	56	51	60	55	51	49	49	49	49
7	72	60	52	47	70	59	52	47	58	51	46	56	50	46	55	50	46	44	44	44	44
8	67	55	47	42	66	54	47	42	53	47	42	52	46	42	51	46	41	40	40	40	40
9	63	51	43	38	62	50	43	38	49	43	38	48	42	38	47	42	38	36	36	36	36
10	59	47	40	35	58	47	40	35	46	39	35	45	39	35	44	39	35	33	33	33	33

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	206947
5°	206233
10°	203964
15°	200460
20°	195963
25°	190724
30°	184715
35°	177602
40°	168649
45°	153326
50°	126583
55°	93215
60°	63270
65°	37035
70°	14619
75°	3275
80°	4316
85°	7330



TEST NUMBER: P840028

CATALOG NUMBER: LDS4C40D010 EU4409040 4LBPSMB

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	158.4	4.9
10°-20°	443.8	13.8
20°-30°	647.3	20.2
30°-40°	738.9	23.0
40°-50°	671.7	20.9
50°-60°	396.2	12.4
60°-70°	132.9	4.1
70°-80°	13.9	0.4
80°-90°	4.8	0.2
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1249.6	39.0
0°-40°	1988.5	62.0
0°-60°	3056.4	95.3
0°-90°	3207.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3207.9	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1684	
5°	1672	158
15°	1576	444
25°	1407	647
35°	1184	739
45°	882	672
55°	435	396
65°	127	133
75°	7	14
85°	5	5
90°	0	



TEST NUMBER: P840028

CATALOG NUMBER: LDS4C40D010 EU4409040 4LBPSMB

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1684.5
2.5°	1681.9
5°	1672.3
7.5°	1656.7
10°	1635.0
12.5°	1607.3
15°	1576.1
17.5°	1539.7
20°	1498.9
22.5°	1454.7
25°	1407.0
27.5°	1355.0
30°	1302.1
32.5°	1244.1
35°	1184.2
37.5°	1119.2
40°	1051.6
42.5°	972.7
45°	882.5
47.5°	778.5
50°	662.3
52.5°	546.2
55°	435.2
57.5°	340.7
60°	257.5
62.5°	186.4
65°	127.4
67.5°	78.0
70°	40.7
72.5°	15.6
75°	6.9
77.5°	6.9
80°	6.1
82.5°	5.2
85°	5.2
87.5°	4.3
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG







— 0°-180°







(END OF REPORT)