

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P858110

Luminaire Tested: **LX4C45D010 EX4C459027 4LBNH**

Issue Date: 2/8/2022



**Test Information**


Test Method: LM-79-08  
Report Number: P858110  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P207666)  
Test Lab: INNOVATION CENTER  
Issue Date: 2/8/2022  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LX4C45D010 EX4C459027 4LBNH  
Description: 4 INCH 4500 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 2700K, 90CRI LEDS  
AND 4LBN TRIM WITH H FINISH  
Light Source: -  
Ballast/Driver:

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2800.0 lumens  
Efficiency: N/A  
Efficacy: 56.5 lumens/watt  
Spacing Criteria (0/90/45): 0.81 / 0.81 / 0.85  
Luminous Opening: Circular (Dia: 0.33' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 49.6  
Input Voltage (V):  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P858110  
CATALOG NUMBER: LX4C45D010 EX4C459027 4LBNH

### Luminous Intensity Polar Plot





TEST NUMBER: P858110

CATALOG NUMBER: LX4C45D010 EX4C459027 4LBNH

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	111	108	106	111	109	106	104	105	103	101	101	99	98	97	96	95	93			
2	108	103	99	96	106	101	98	94	98	95	92	95	93	90	92	90	89	87			
3	102	96	91	87	100	95	90	86	92	88	85	90	86	84	87	85	82	81			
4	97	90	84	80	95	89	83	79	86	82	78	84	81	78	83	79	77	75			
5	92	84	78	74	91	83	78	73	81	76	73	80	75	72	78	74	72	70			
6	88	79	73	69	86	78	72	68	77	72	68	75	71	67	74	70	67	65			
7	83	74	68	64	82	73	68	64	72	67	63	71	66	63	70	66	63	61			
8	79	70	64	60	78	69	64	60	68	63	59	67	63	59	66	62	59	58			
9	76	66	60	56	74	65	60	56	65	59	56	64	59	56	63	59	55	54			
10	72	62	57	53	71	62	56	53	61	56	53	60	56	52	60	55	52	51			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	431891
5°	422282
10°	390438
15°	350350
20°	308398
25°	265414
30°	213739
35°	142283
40°	74013
45°	33497
50°	14545
55°	9767
60°	6241
65°	4448
70°	3664
75°	2421
80°	0
85°	0



TEST NUMBER: P858110

CATALOG NUMBER: LX4C45D010 EX4C459027 4LBNH

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	317.2	11.3
10°-20°	769.4	27.5
20°-30°	893.3	31.9
30°-40°	591.5	21.1
40°-50°	165.9	5.9
50°-60°	41.7	1.5
60°-70°	15.7	0.6
70°-80°	5.4	0.2
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1979.8	70.7
0°-40°	2571.4	91.8
0°-60°	2779.0	99.2
0°-90°	2800.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2800.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3516	
5°	3424	317
15°	2755	769
25°	1958	893
35°	949	592
45°	193	166
55°	46	42
65°	15	16
75°	5	5
85°	0	0
90°	0	



TEST NUMBER: P858110

CATALOG NUMBER: LX4C45D010 EX4C459027 4LBNH

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	3515.5
2.5°	3500.3
5°	3424.2
7.5°	3292.2
10°	3129.8
12.5°	2947.2
15°	2754.6
17.5°	2566.8
20°	2358.9
22.5°	2166.1
25°	1958.0
27.5°	1760.3
30°	1506.7
32.5°	1237.7
35°	948.7
37.5°	679.8
40°	461.5
42.5°	299.2
45°	192.8
47.5°	116.8
50°	76.1
52.5°	55.7
55°	45.6
57.5°	35.6
60°	25.4
62.5°	20.3
65°	15.3
67.5°	10.2
70°	10.2
72.5°	5.1
75°	5.1
77.5°	5.1
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG







— 0°-180°







(END OF REPORT)