

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P777697

Luminaire Tested: LERS4D08D010-EC4DR300210IC9050-4LBS1H

Issue Date: 1/30/2024

Test Information

Test Method: LM-79-2019
Report Number: P777697
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 1/30/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LERS4D08D010-EC4DR300210IC9050-4LBS1H
Description: 4 INCH ROUND SHALLOW SEMI-SPECULAR CLEAR TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 5000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 823.8 lumens
Efficiency: N/A
Efficacy: 92.6 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct

Input Watts (W): 8.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P777697

CATALOG NUMBER: LERS4D08D010-EC4DR300210IC9050-4LBS1H

Luminous Intensity Polar Plot





TEST NUMBER: P777697

CATALOG NUMBER: LERS4D08D010-EC4DR300210IC9050-4LBS1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0													
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96																			
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92																			
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89																			
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85																			
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82																			
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79																			
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77																			
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74																			
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72																			
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69																			

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	202756	202756	202756
5°	196930	196707	196945
10°	170574	169377	170535
15°	111290	110695	110141
20°	55341	57418	55268
25°	27879	31435	27305
30°	11163	12162	9722
35°	5177	4962	4158
40°	2228	2488	2108
45°	1580	1959	1591
50°	536	1429	572
55°	307	587	334
60°	214	260	214
65°	145	145	145
70°	90	67	90
75°	0	30	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°

Vertical Angle: 45°

Luminance: 1959 cd/sqm



TEST NUMBER: P777697

CATALOG NUMBER: LERS4D08D010-EC4DR300210IC9050-4LBS1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	232.9	28.3
10°-20°	375.1	45.5
20°-30°	162.1	19.7
30°-40°	37.0	4.5
40°-50°	12.7	1.5
50°-60°	3.1	0.4
60°-70°	0.8	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	770.2	93.5
0°-40°	807.1	98.0
0°-60°	822.9	99.9
0°-90°	823.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	823.8	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2649	2649	2649	2649	2649	
5°	2563	2561	2560	2565	2563	233
15°	1404	1388	1397	1392	1390	376
25°	330	343	372	334	323	158
35°	55	57	53	53	44	38
45°	15	18	18	18	15	10
55°	2	2	4	3	2	2
65°	1	1	1	1	1	1
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P777697

CATALOG NUMBER: LERS4D08D010-EC4DR300210IC9050-4LBS1H

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2648.9	2648.9	2648.9	2648.9	2648.9
2.5°	2631.3	2629.5	2630.5	2631.8	2632.4
5°	2563.0	2560.6	2560.1	2565.4	2563.2
7.5°	2425.3	2421.8	2416.5	2428.6	2439.9
10°	2194.6	2190.7	2179.2	2184.9	2194.1
12.5°	1854.0	1841.4	1841.1	1859.3	1856.9
15°	1404.4	1387.5	1396.9	1392.3	1389.9
17.5°	944.5	937.9	950.4	946.6	930.4
20°	679.4	681.1	704.9	692.9	678.5
22.5°	495.8	501.8	530.1	499.3	487.9
25°	330.1	342.6	372.2	333.9	323.3
27.5°	203.0	208.7	238.7	200.4	194.7
30°	126.3	123.4	137.6	118.1	110.0
32.5°	82.8	79.2	83.8	75.2	68.6
35°	55.4	56.6	53.1	52.7	44.5
37.5°	34.6	39.8	35.1	37.5	28.6
40°	22.3	28.9	24.9	27.4	21.1
42.5°	18.3	22.2	20.4	21.7	18.7
45°	14.6	18.1	18.1	18.1	14.7
47.5°	8.1	12.1	15.5	12.4	8.6
50°	4.5	6.1	12.0	6.4	4.8
52.5°	3.1	3.5	8.2	3.7	3.3
55°	2.3	2.5	4.4	2.6	2.5
57.5°	1.8	1.9	2.3	1.9	1.8
60°	1.4	1.4	1.7	1.5	1.4
62.5°	1.0	1.0	1.1	1.0	1.0
65°	0.8	0.8	0.8	0.8	0.8
67.5°	0.4	0.5	0.5	0.5	0.5
70°	0.4	0.3	0.3	0.3	0.4
72.5°	0.3	0.1	0.1	0.1	0.1
75°	0.0	0.0	0.1	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)