

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211111

Luminaire Tested: **LE\_4B15D010 EC4B10208027 4LBS1LI**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P211111  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LE\_4B15D010 EC4B10208027 4LBS1LI  
Description: PORTFOLIO 4 INCH CYLINDER  
SHALLOW DISTRIBUTION WITH SPECULAR CLEAR TRIM  
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W  
DL3-15.28W DLE-15.432W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1699.7 lumens  
Efficiency: N/A  
Efficacy: 118.9 lumens/watt  
Spacing Criteria (0/90/45): 0.91 / 0.91 / 1  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 14.3  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P211111

CATALOG NUMBER: LE\_4B15D010 EC4B10208027 4LBS1LI

### Luminous Intensity Polar Plot






TEST NUMBER: P211111

CATALOG NUMBER: LE\_4B15D010 EC4B10208027 4LBS1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

|     |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|--|-----|-----|-----|--|-----|
| RF  | 20  |     |     |     | 20  |     |     |     | 20  |     |     |  | 20  |     |     |  | 20  |
| RC  | 80  |     |     |     | 70  |     |     |     | 50  |     |     |  | 30  |     |     |  | 10  |
| RW  | 70  | 50  | 30  | 10  | 70  | 50  | 30  | 10  | 50  | 30  | 10  |  | 50  | 30  | 10  |  | 50  |
| RCR |     |     |     |     |     |     |     |     |     |     |     |  |     |     |     |  |     |
| 0   | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 |  | 106 | 106 | 106 |  | 102 |
| 1   | 112 | 108 | 105 | 102 | 109 | 106 | 103 | 101 | 102 | 100 | 98  |  | 98  | 96  | 95  |  | 95  |
| 2   | 104 | 98  | 93  | 88  | 102 | 96  | 91  | 87  | 93  | 89  | 85  |  | 90  | 86  | 84  |  | 87  |
| 3   | 97  | 89  | 82  | 77  | 95  | 87  | 81  | 77  | 84  | 79  | 75  |  | 82  | 78  | 74  |  | 79  |
| 4   | 90  | 81  | 73  | 68  | 88  | 79  | 73  | 68  | 77  | 71  | 67  |  | 75  | 70  | 66  |  | 73  |
| 5   | 84  | 73  | 66  | 61  | 82  | 72  | 65  | 60  | 70  | 64  | 60  |  | 69  | 63  | 59  |  | 67  |
| 6   | 79  | 67  | 60  | 54  | 77  | 66  | 59  | 54  | 65  | 58  | 54  |  | 63  | 58  | 53  |  | 62  |
| 7   | 74  | 62  | 54  | 49  | 72  | 61  | 54  | 49  | 60  | 53  | 49  |  | 58  | 53  | 48  |  | 57  |
| 8   | 69  | 57  | 50  | 45  | 68  | 57  | 50  | 45  | 55  | 49  | 45  |  | 54  | 49  | 44  |  | 53  |
| 9   | 65  | 53  | 46  | 41  | 64  | 53  | 46  | 41  | 52  | 45  | 41  |  | 51  | 45  | 41  |  | 50  |
| 10  | 61  | 50  | 43  | 38  | 60  | 49  | 42  | 38  | 48  | 42  | 38  |  | 47  | 42  | 38  |  | 46  |

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P211111

CATALOG NUMBER: LE\_4B15D010 EC4B10208027 4LBS1LI

**ZONAL LUMENS:**

| Zone      | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10°    | 110.0  | 6.5       |
| 10°-20°   | 280.7  | 16.5      |
| 20°-30°   | 363.7  | 21.4      |
| 30°-40°   | 356.3  | 21.0      |
| 40°-50°   | 302.0  | 17.8      |
| 50°-60°   | 198.0  | 11.6      |
| 60°-70°   | 79.6   | 4.7       |
| 70°-80°   | 9.1    | 0.5       |
| 80°-90°   | 0.3    | 0.0       |
| 90°-100°  | 0.0    | 0.0       |
| 100°-110° | 0.0    | 0.0       |
| 110°-120° | 0.0    | 0.0       |
| 120°-130° | 0.0    | 0.0       |
| 130°-140° | 0.0    | 0.0       |
| 140°-150° | 0.0    | 0.0       |
| 150°-160° | 0.0    | 0.0       |
| 160°-170° | 0.0    | 0.0       |
| 170°-180° | 0.0    | 0.0       |
| 0°-30°    | 754.4  | 44.4      |
| 0°-40°    | 1110.7 | 65.3      |
| 0°-60°    | 1610.7 | 94.8      |
| 0°-90°    | 1699.7 | 100.0     |
| 90°-120°  | 0.0    | 0.0       |
| 90°-150°  | 0.0    | 0.0       |
| 90°-180°  | 0.0    | 0.0       |
| 0°-180°   | 1699.7 | 100.0     |

**CANDELA DISTRIBUTION:**

|     | 0°   | Flux |
|-----|------|------|
| 0°  | 1214 |      |
| 5°  | 1182 | 110  |
| 15° | 1001 | 281  |
| 25° | 794  | 364  |
| 35° | 566  | 356  |
| 45° | 393  | 302  |
| 55° | 220  | 198  |
| 65° | 77   | 80   |
| 75° | 4    | 9    |
| 85° | 0    | 0    |
| 90° | 0    |      |



TEST NUMBER: P211111

CATALOG NUMBER: LE\_4B15D010 EC4B10208027 4LBS1LI

**CANDELA DISTRIBUTION (FULL):**

|       | 0°     |
|-------|--------|
| 0°    | 1213.6 |
| 2.5°  | 1204.2 |
| 5°    | 1181.7 |
| 7.5°  | 1144.0 |
| 10°   | 1097.0 |
| 12.5° | 1046.2 |
| 15°   | 1001.0 |
| 17.5° | 952.1  |
| 20°   | 903.2  |
| 22.5° | 850.5  |
| 25°   | 794.0  |
| 27.5° | 735.7  |
| 30°   | 675.5  |
| 32.5° | 619.1  |
| 35°   | 566.3  |
| 37.5° | 523.0  |
| 40°   | 476.1  |
| 42.5° | 434.7  |
| 45°   | 393.2  |
| 47.5° | 350.0  |
| 50°   | 306.7  |
| 52.5° | 263.4  |
| 55°   | 220.2  |
| 57.5° | 180.6  |
| 60°   | 143.0  |
| 62.5° | 109.2  |
| 65°   | 77.1   |
| 67.5° | 50.8   |
| 70°   | 30.2   |
| 72.5° | 13.2   |
| 75°   | 3.7    |
| 77.5° | 1.9    |
| 80°   | 1.9    |
| 82.5° | 0.0    |
| 85°   | 0.0    |
| 87.5° | 0.0    |
| 90°   | 0.0    |



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)