

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211235

Luminaire Tested: **LE_4B15D010 EC4B10209030 4LBW1MW**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211235
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B15D010 EC4B10209030 4LBW1MW
Description: PORTFOLIO 4 INCH CYLINDER
WIDE DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1294.0 lumens
Efficiency: N/A
Efficacy: 90.5 lumens/watt
Spacing Criteria (0/90/45): 1.1 / 1.1 / 1.09
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211235

CATALOG NUMBER: LE_4B15D010 EC4B10209030 4LBW1MW

Luminous Intensity Polar Plot





TEST NUMBER: P211235

CATALOG NUMBER: LE_4B15D010 EC4B10209030 4LBW1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	111	107	104	101	108	105	102	99	101	98	96		97	95	93		93
2	103	96	91	86	101	94	89	85	91	87	83		88	84	81		85
3	96	87	80	75	93	85	79	74	83	77	73		80	76	72		78
4	89	79	72	66	87	78	71	66	75	69	65		73	68	64		71
5	83	72	64	59	81	71	64	58	69	63	58		67	62	57		65
6	78	66	58	53	76	65	58	53	64	57	52		62	56	52		60
7	73	61	53	48	71	60	53	48	59	52	47		57	51	47		56
8	68	56	49	44	67	56	49	44	54	48	43		53	47	43		52
9	64	52	45	40	63	52	45	40	51	44	40		50	44	40		49
10	61	49	42	37	59	48	41	37	47	41	37		46	41	37		46

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211235

CATALOG NUMBER: LE_4B15D010 EC4B10209030 4LBW1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	73.6	5.7
10°-20°	205.9	15.9
20°-30°	291.0	22.5
30°-40°	281.9	21.8
40°-50°	190.2	14.7
50°-60°	118.0	9.1
60°-70°	78.9	6.1
70°-80°	43.1	3.3
80°-90°	11.4	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	570.5	44.1
0°-40°	852.3	65.9
0°-60°	1160.5	89.7
0°-90°	1294.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1294.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	784	
5°	777	74
15°	730	206
25°	638	291
35°	453	282
45°	244	190
55°	129	118
65°	79	79
75°	40	43
85°	10	11
90°	0	



TEST NUMBER: P211235

CATALOG NUMBER: LE_4B15D010 EC4B10209030 4LBW1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	784.2
2.5°	784.2
5°	777.4
7.5°	769.1
10°	759.0
12.5°	748.9
15°	730.5
17.5°	715.3
20°	690.1
22.5°	664.9
25°	638.0
27.5°	601.1
30°	560.9
32.5°	508.8
35°	453.3
37.5°	398.0
40°	342.5
42.5°	287.1
45°	243.5
47.5°	203.1
50°	173.0
52.5°	147.8
55°	129.3
57.5°	114.1
60°	102.4
62.5°	90.7
65°	78.9
67.5°	68.8
70°	58.8
72.5°	50.3
75°	40.3
77.5°	31.9
80°	23.5
82.5°	16.8
85°	10.1
87.5°	3.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)