

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211319

Luminaire Tested: **LE_4B15D010 EC4B10209035 4LBW1GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211319
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B15D010 EC4B10209035 4LBW1GPH
Description: PORTFOLIO 4 INCH CYLINDER
WIDE DISTRIBUTIONWITH GRAPHITE HAZE TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 983.3 lumens
Efficiency: N/A
Efficacy: 68.8 lumens/watt
Spacing Criteria (0/90/45): 1.12 / 1.12 / 1.08
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211319

CATALOG NUMBER: LE_4B15D010 EC4B10209035 4LBW1GPH

Luminous Intensity Polar Plot





TEST NUMBER: P211319

CATALOG NUMBER: LE_4B15D010 EC4B10209035 4LBW1GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	113	110	107	104	110	107	105	103	103	101	99		100	98	96		96
2	106	100	96	92	104	99	95	91	95	92	89		92	90	87		90
3	100	92	87	82	98	91	86	81	88	84	80		86	82	79		83
4	94	85	78	74	92	84	78	73	81	76	72		79	75	71		77
5	88	78	72	67	86	77	71	66	75	70	66		74	69	65		72
6	83	72	65	61	81	71	65	60	70	64	60		68	63	59		67
7	78	67	60	55	76	66	60	55	65	59	55		64	58	55		63
8	73	62	56	51	72	62	55	51	61	55	51		59	54	50		58
9	69	58	51	47	68	58	51	47	57	51	47		56	50	46		55
10	65	54	48	43	64	54	48	43	53	47	43		52	47	43		51

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211319

CATALOG NUMBER: LE_4B15D010 EC4B10209035 4LBW1GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	66.8	6.8
10°-20°	189.2	19.2
20°-30°	271.3	27.6
30°-40°	255.5	26.0
40°-50°	141.1	14.3
50°-60°	45.3	4.6
60°-70°	11.3	1.1
70°-80°	2.7	0.3
80°-90°	0.2	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	527.3	53.6
0°-40°	782.7	79.6
0°-60°	969.1	98.6
0°-90°	983.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	983.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	708	
5°	704	67
15°	670	189
25°	595	271
35°	414	255
45°	179	141
55°	46	45
65°	10	11
75°	2	3
85°	0	0
90°	0	



TEST NUMBER: P211319

CATALOG NUMBER: LE_4B15D010 EC4B10209035 4LBW1GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	707.7
2.5°	702.6
5°	704.4
7.5°	699.2
10°	690.7
12.5°	682.2
15°	670.2
17.5°	659.9
20°	642.9
22.5°	619.1
25°	595.2
27.5°	562.7
30°	520.1
32.5°	472.4
35°	414.4
37.5°	353.0
40°	289.9
42.5°	231.9
45°	179.1
47.5°	134.7
50°	97.2
52.5°	68.2
55°	46.1
57.5°	30.7
60°	22.2
62.5°	15.3
65°	10.2
67.5°	6.8
70°	5.1
72.5°	3.4
75°	1.7
77.5°	1.7
80°	1.7
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)