

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211841

Luminaire Tested: **LE_4B30D010 EC4B30509024 4LBW1GPH**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211841
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B30D010 EC4B30509024 4LBW1GPH
Description: PORTFOLIO 4 INCH CYLINDER
WIDE DISTRIBUTIONWITH GRAPHITE HAZE TRIM
WATTAGE D010TR-27.4W DE010-27.95W D5LT-27.65W DMX-27.73W DL2-29.56W
DL3-29.67W DLE-29.73W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 1600.9 lumens
Efficiency: N/A
Efficacy: 57.2 lumens/watt
Spacing Criteria (0/90/45): 1.12 / 1.12 / 1.08
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct

Input Watts (W): 28
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211841
CATALOG NUMBER: LE_4B30D010 EC4B30509024 4LBW1GPH

Luminous Intensity Polar Plot





TEST NUMBER: P211841

CATALOG NUMBER: LE_4B30D010 EC4B30509024 4LBW1GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	113	110	107	104	110	107	105	103	103	101	99	100	98	96	96	95	94	92				92
2	106	100	96	92	104	99	95	91	95	92	89	92	90	87	90	87	85	83				83
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	77	76				76
4	94	85	78	74	92	84	78	73	81	76	72	79	75	71	77	74	71	69				69
5	88	78	72	67	86	77	71	66	75	70	66	74	69	65	72	68	64	63				63
6	83	72	65	61	81	71	65	60	70	64	60	68	63	59	67	63	59	57				57
7	78	67	60	55	76	66	60	55	65	59	55	64	58	55	63	58	54	53				53
8	73	62	56	51	72	62	55	51	61	55	50	59	54	50	58	54	50	48				48
9	69	58	51	47	68	58	51	47	57	51	47	56	50	46	55	50	46	45				45
10	65	54	48	43	64	54	48	43	53	47	43	52	47	43	51	46	43	41				41

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211841

CATALOG NUMBER: LE_4B30D010 EC4B30509024 4LBW1GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	108.7	6.8
10°-20°	308.0	19.2
20°-30°	441.7	27.6
30°-40°	415.9	26.0
40°-50°	229.7	14.3
50°-60°	73.6	4.6
60°-70°	18.4	1.2
70°-80°	4.4	0.3
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	858.4	53.6
0°-40°	1274.3	79.6
0°-60°	1577.6	98.5
0°-90°	1600.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1600.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1152	
5°	1147	109
15°	1091	308
25°	969	442
35°	675	416
45°	292	230
55°	75	74
65°	17	18
75°	3	4
85°	0	0
90°	0	



TEST NUMBER: P211841

CATALOG NUMBER: LE_4B30D010 EC4B30509024 4LBW1GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	1152.2
2.5°	1143.9
5°	1146.7
7.5°	1138.3
10°	1124.5
12.5°	1110.6
15°	1091.1
17.5°	1074.5
20°	1046.7
22.5°	1007.8
25°	968.9
27.5°	916.2
30°	846.8
32.5°	769.1
35°	674.7
37.5°	574.7
40°	472.0
42.5°	377.6
45°	291.5
47.5°	219.4
50°	158.2
52.5°	111.0
55°	74.9
57.5°	50.0
60°	36.1
62.5°	24.9
65°	16.7
67.5°	11.1
70°	8.4
72.5°	5.6
75°	2.8
77.5°	2.8
80°	2.8
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)