

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211920

Luminaire Tested: **LE_4B30D010 EC4B30509727 4LBS1B**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211920
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LE_4B30D010 EC4B30509727 4LBS1B
Description: PORTFOLIO 4 INCH CYLINDER
SHALLOW DISTRIBUTION WITH SPECULAR BLACK TRIM
WATTAGE D010TR-27.4W DE010-27.95W D5LT-27.65W DMX-27.73W DL2-29.56W
DL3-29.67W DLE-29.73W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2923.1 lumens
Efficiency: N/A
Efficacy: 104.4 lumens/watt
Spacing Criteria (0/90/45): 1.2 / 1.2 / 1.3
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211920

CATALOG NUMBER: LE_4B30D010 EC4B30509727 4LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P211920

CATALOG NUMBER: LE_4B30D010 EC4B30509727 4LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	111	107	103	100	108	105	101	98	100	98	95	97	94	93	93	91	90	88				88
2	102	95	89	84	100	93	88	83	90	85	81	86	83	79	84	80	78	76				76
3	94	84	77	72	91	83	76	71	80	74	70	77	73	68	75	71	67	65				65
4	86	76	68	62	84	74	67	61	72	65	60	70	64	60	68	63	59	57				57
5	80	68	60	54	78	67	59	53	65	58	53	63	57	52	61	56	52	50				50
6	74	62	53	47	72	61	53	47	59	52	47	57	51	46	56	50	46	44				44
7	69	56	48	42	67	55	48	42	54	47	42	52	46	41	51	45	41	39				39
8	64	51	43	38	63	51	43	38	49	42	37	48	42	37	47	41	37	35				35
9	60	47	39	34	59	47	39	34	46	39	34	45	38	34	44	38	34	32				32
10	56	44	36	31	55	43	36	31	42	36	31	41	35	31	40	35	31	29				29

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211920

CATALOG NUMBER: LE_4B30D010 EC4B30509727 4LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	121.7	4.2
10°-20°	345.3	11.8
20°-30°	513.7	17.6
30°-40°	597.8	20.4
40°-50°	582.6	19.9
50°-60°	448.1	15.3
60°-70°	247.7	8.5
70°-80°	65.6	2.2
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	980.7	33.6
0°-40°	1578.5	54.0
0°-60°	2609.2	89.3
0°-90°	2923.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2923.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1290	
5°	1282	122
15°	1223	345
25°	1115	514
35°	960	598
45°	756	583
55°	500	448
65°	248	248
75°	56	66
85°	0	1
90°	0	



TEST NUMBER: P211920

CATALOG NUMBER: LE_4B30D010 EC4B30509727 4LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	1289.5
2.5°	1289.5
5°	1282.0
7.5°	1271.0
10°	1263.6
12.5°	1241.3
15°	1222.8
17.5°	1204.3
20°	1178.3
22.5°	1152.3
25°	1115.3
27.5°	1078.3
30°	1041.2
32.5°	1000.5
35°	959.7
37.5°	907.8
40°	863.4
42.5°	815.2
45°	755.9
47.5°	700.3
50°	637.3
52.5°	570.6
55°	500.2
57.5°	433.5
60°	370.5
62.5°	307.5
65°	248.2
67.5°	192.7
70°	140.8
72.5°	96.4
75°	55.6
77.5°	26.0
80°	3.7
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)