

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211930

Luminaire Tested: **LE\_4B30D010 EC4B30509727 4LBW1LI**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P211930  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LE\_4B30D010 EC4B30509727 4LBW1LI  
Description: PORTFOLIO 4 INCH CYLINDER  
WIDE DISTRIBUTION WITH SPECULAR CLEAR TRIM  
WATTAGE D010TR-27.4W DE010-27.95W D5LT-27.65W DMX-27.73W DL2-29.56W  
DL3-29.67W DLE-29.73W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2393.9 lumens  
Efficiency: N/A  
Efficacy: 85.5 lumens/watt  
Spacing Criteria (0/90/45): 1.29 / 1.29 / 1.18  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 28  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P211930

CATALOG NUMBER: LE\_4B30D010 EC4B30509727 4LBW1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P211930

CATALOG NUMBER: LE\_4B30D010 EC4B30509727 4LBW1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	96	95	94	92	92	92	92
2	106	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84	84	84	84
3	100	93	87	83	98	92	86	82	89	85	81	86	83	80	84	81	78	77	77	77	77
4	94	86	79	75	92	84	79	74	82	77	73	80	76	72	78	75	72	70	70	70	70
5	88	79	72	68	87	78	72	67	76	71	67	74	70	66	73	69	65	64	64	64	64
6	83	73	66	62	82	72	66	61	71	65	61	69	64	60	68	63	60	58	58	58	58
7	78	68	61	56	77	67	61	56	66	60	56	64	59	55	63	59	55	54	54	54	54
8	74	63	56	52	72	62	56	51	61	55	51	60	55	51	59	54	51	49	49	49	49
9	69	59	52	48	68	58	52	47	57	51	47	56	51	47	55	50	47	45	45	45	45
10	66	55	48	44	65	54	48	44	53	48	44	53	47	44	52	47	43	42	42	42	42

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P211930

CATALOG NUMBER: LE\_4B30D010 EC4B30509727 4LBW1LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	143.4	6.0
10°-20°	452.7	18.9
20°-30°	706.1	29.5
30°-40°	687.1	28.7
40°-50°	343.2	14.3
50°-60°	53.1	2.2
60°-70°	6.4	0.3
70°-80°	1.8	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1302.2	54.4
0°-40°	1989.3	83.1
0°-60°	2385.6	99.7
0°-90°	2393.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2393.9	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1467	
5°	1486	143
15°	1598	453
25°	1552	706
35°	1116	687
45°	430	343
55°	44	53
65°	6	6
75°	3	2
85°	0	0
90°	0	



TEST NUMBER: P211930

CATALOG NUMBER: LE\_4B30D010 EC4B30509727 4LBW1LI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	1466.7
2.5°	1472.2
5°	1486.0
7.5°	1507.9
10°	1535.3
12.5°	1570.9
15°	1598.4
17.5°	1620.3
20°	1623.0
22.5°	1603.8
25°	1551.7
27.5°	1474.9
30°	1379.0
32.5°	1258.4
35°	1115.8
37.5°	959.6
40°	795.1
42.5°	619.6
45°	430.5
47.5°	276.9
50°	167.3
52.5°	90.5
55°	43.8
57.5°	19.1
60°	11.0
62.5°	8.2
65°	5.5
67.5°	5.5
70°	2.8
72.5°	2.8
75°	2.8
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)