

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211421

Luminaire Tested: **LSR4B15D010BZ EC4B10209050 4LBNGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211421
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR4B15D010BZ EC4B10209050 4LBNGPH1
Description: PORTFOLIO 4 INCH CYLINDER
NARROW DISTRIBUTION WITH GRAPHITE HAZE TRIM
WATTAGE D010TR-14.39W DE010-14.29W D5LT-14.34W DMX-14.46W DL2-15.8W
DL3-15.28W DLE-15.432W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 610.1 lumens
Efficiency: N/A
Efficacy: 42.7 lumens/watt
Spacing Criteria (0/90/45): 0.86 / 0.86 / 0.88
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211421

CATALOG NUMBER: LSR4B15D010BZ EC4B10209050 4LBNGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P211421

CATALOG NUMBER: LSR4B15D010BZ EC4B10209050 4LBNGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	111	108	106	111	109	106	104	105	103	101	101	100	98	97	96	95	94
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	92	91	89	87
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81
4	97	90	84	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76
5	93	84	78	74	91	83	78	74	82	77	73	80	76	73	78	75	72	70
6	88	79	73	69	86	78	73	69	77	72	68	75	71	68	74	70	67	66
7	84	74	68	64	82	74	68	64	72	67	64	71	67	63	70	66	63	62
8	80	70	64	60	78	70	64	60	68	63	60	67	63	59	66	62	59	58
9	76	66	60	56	75	66	60	56	65	60	56	64	59	56	63	59	56	54
10	72	63	57	53	71	62	57	53	61	56	53	61	56	53	60	56	52	51

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211421

CATALOG NUMBER: LSR4B15D010BZ EC4B10209050 4LBNGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	66.5	10.9
10°-20°	166.8	27.3
20°-30°	203.2	33.3
30°-40°	134.1	22.0
40°-50°	30.9	5.1
50°-60°	5.9	1.0
60°-70°	2.2	0.4
70°-80°	0.6	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	436.5	71.5
0°-40°	570.6	93.5
0°-60°	607.4	99.5
0°-90°	610.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	610.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	732	
5°	714	67
15°	597	167
25°	446	203
35°	214	134
45°	34	31
55°	6	6
65°	2	2
75°	0	1
85°	0	0
90°	0	



TEST NUMBER: P211421

CATALOG NUMBER: LSR4B15D010BZ EC4B10209050 4LBNGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	731.7
2.5°	730.2
5°	714.0
7.5°	691.8
10°	662.2
12.5°	632.7
15°	597.2
17.5°	560.2
20°	521.8
22.5°	487.8
25°	446.4
27.5°	405.0
30°	351.8
32.5°	286.8
35°	214.3
37.5°	149.3
40°	96.1
42.5°	59.1
45°	34.0
47.5°	17.7
50°	10.3
52.5°	8.9
55°	5.9
57.5°	4.4
60°	4.4
62.5°	3.0
65°	1.5
67.5°	1.5
70°	1.5
72.5°	1.5
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)