

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211457

Luminaire Tested: **LSR4B20D010BZ EC4B10209024 4LBSGPH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P211457  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR4B20D010BZ EC4B10209024 4LBSGPH1  
Description: PORTFOLIO 4 INCH CYLINDER  
SHALLOW DISTRIBUTION WITH GRAPHITE HAZE TRIM  
WATTAGE D010TR-21.86W DE010-20.46W D5LT-21.24W DMX-20.89W DL2-22.5W  
DL3-21.8 6W DLE-22.46W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1318.4 lumens  
Efficiency: N/A  
Efficacy: 63.4 lumens/watt  
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.26  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 20.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P211457

CATALOG NUMBER: LSR4B20D010BZ EC4B10209024 4LBSGPH1

### Luminous Intensity Polar Plot





TEST NUMBER: P211457

CATALOG NUMBER: LSR4B20D010BZ EC4B10209024 4LBSGPH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	107	103	100	108	105	102	99	101	98	96	97	95	93	93	91	90	88																			
2	102	95	89	84	100	93	88	83	90	85	82	87	83	80	84	81	78	76																			
3	94	85	78	72	92	83	77	71	80	75	70	78	73	69	75	71	68	66																			
4	87	76	68	62	85	75	67	62	72	66	61	70	65	60	68	63	59	57																			
5	80	68	60	54	78	67	60	54	65	59	53	63	58	53	62	56	52	50																			
6	74	62	54	48	73	61	53	48	59	52	47	58	52	47	56	51	47	45																			
7	69	57	48	43	68	56	48	43	54	47	42	53	47	42	52	46	42	40																			
8	65	52	44	38	63	51	44	38	50	43	38	49	42	38	48	42	38	36																			
9	60	48	40	35	59	47	40	35	46	39	35	45	39	34	44	38	34	32																			
10	57	44	37	32	56	44	36	32	43	36	31	42	36	31	41	35	31	30																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P211457

CATALOG NUMBER: LSR4B20D010BZ EC4B10209024 4LBSGPH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	57.6	4.4
10°-20°	161.8	12.3
20°-30°	236.0	17.9
30°-40°	269.2	20.4
40°-50°	258.2	19.6
50°-60°	197.7	15.0
60°-70°	108.5	8.2
70°-80°	28.8	2.2
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	455.5	34.5
0°-40°	724.7	55.0
0°-60°	1180.6	89.5
0°-90°	1318.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1318.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	612	
5°	608	58
15°	574	162
25°	513	236
35°	430	269
45°	335	258
55°	222	198
65°	109	109
75°	25	29
85°	0	0
90°	0	



TEST NUMBER: P211457

CATALOG NUMBER: LSR4B20D010BZ EC4B10209024 4LBSGPH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	612.3
2.5°	610.7
5°	607.6
7.5°	602.8
10°	596.5
12.5°	585.4
15°	574.3
17.5°	561.7
20°	547.5
22.5°	530.0
25°	512.6
27.5°	495.2
30°	473.1
32.5°	452.5
35°	430.4
37.5°	408.2
40°	386.1
42.5°	362.3
45°	335.4
47.5°	308.5
50°	280.1
52.5°	250.0
55°	221.5
57.5°	193.0
60°	163.0
62.5°	134.5
65°	109.2
67.5°	83.9
70°	61.7
72.5°	41.1
75°	25.3
77.5°	11.1
80°	3.2
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)