

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211473

Luminaire Tested: **LSR4B20D010BZ EC4B10208027 4LBMGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P211473
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR4B20D010BZ EC4B10208027 4LBMGPH1
Description: PORTFOLIO 4 INCH CYLINDER
MEDIUM DISTRIBUTION WITH GRAPHITE HAZE TRIM
WATTAGE D010TR-21.86W DE010-20.46W D5LT-21.24W DMX-20.89W DL2-22.5W
DL3-21.8 6W DLE-22.46W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1046.1 lumens
Efficiency: N/A
Efficacy: 50.3 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.92
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 20.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P211473

CATALOG NUMBER: LSR4B20D010BZ EC4B10208027 4LBMGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P211473

CATALOG NUMBER: LSR4B20D010BZ EC4B10208027 4LBMGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	108	105	111	108	106	104	104	102	101	100	99	98	97	96	95	93																			
2	107	102	98	94	105	100	97	93	97	94	91	94	92	89	91	89	88	86																			
3	102	95	90	85	100	93	89	85	91	87	83	88	85	82	86	83	81	79																			
4	96	88	82	78	94	87	82	78	85	80	77	83	79	76	81	78	75	73																			
5	91	82	76	72	89	81	76	71	79	74	71	78	73	70	76	72	69	68																			
6	86	77	71	66	85	76	70	66	74	69	65	73	68	65	72	68	64	63																			
7	82	72	66	61	80	71	65	61	70	65	61	69	64	60	68	63	60	59																			
8	77	67	61	57	76	67	61	57	66	60	57	65	60	56	64	59	56	55																			
9	73	63	57	53	72	63	57	53	62	57	53	61	56	53	60	56	52	51																			
10	70	60	54	50	69	59	54	50	59	53	50	58	53	49	57	52	49	48																			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P211473

CATALOG NUMBER: LSR4B20D010BZ EC4B10208027 4LBMGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	99.0	9.5
10°-20°	258.1	24.7
20°-30°	331.0	31.6
30°-40°	239.2	22.9
40°-50°	85.8	8.2
50°-60°	23.2	2.2
60°-70°	7.6	0.7
70°-80°	2.3	0.2
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	688.0	65.8
0°-40°	927.3	88.6
0°-60°	1036.2	99.1
0°-90°	1046.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1046.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1076	
5°	1056	99
15°	919	258
25°	730	331
35°	383	239
45°	103	86
55°	24	23
65°	7	8
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P211473

CATALOG NUMBER: LSR4B20D010BZ EC4B10208027 4LBMGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1075.5
2.5°	1071.1
5°	1055.7
7.5°	1031.5
10°	998.5
12.5°	961.1
15°	919.3
17.5°	877.5
20°	835.7
22.5°	787.4
25°	730.2
27.5°	664.2
30°	580.6
32.5°	483.8
35°	382.7
37.5°	290.3
40°	211.1
42.5°	149.6
45°	103.4
47.5°	70.4
50°	46.2
52.5°	33.0
55°	24.2
57.5°	17.6
60°	13.2
62.5°	11.0
65°	6.6
67.5°	4.4
70°	4.4
72.5°	2.2
75°	2.2
77.5°	2.2
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)