

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P211851

Luminaire Tested: **LSR4B30D010BZ EC4B30508027 4LBMH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P211851  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR4B30D010BZ EC4B30508027 4LBMH1  
Description: PORTFOLIO 4 INCH CYLINDER  
MEDIUM DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM  
WATTAGE D010TR-27.4W DE010-27.95W D5LT-27.65W DMX-27.73W DL2-29.56W  
DL3-29.67W DLE-29.73W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2099.2 lumens  
Efficiency: N/A  
Efficacy: 75.0 lumens/watt  
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.93  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 28  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P211851

CATALOG NUMBER: LSR4B30D010BZ EC4B30508027 4LBMH1

### Luminous Intensity Polar Plot





TEST NUMBER: P211851

CATALOG NUMBER: LSR4B30D010BZ EC4B30508027 4LBMH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	110	108	105	111	108	106	104	104	102	100	100	99	97	97	96	95	93			
2	107	102	98	94	105	100	96	93	97	94	91	94	91	89	91	89	87	85			
3	101	94	89	85	99	93	88	84	90	86	83	88	84	82	86	83	80	79			
4	96	88	82	77	94	86	81	77	84	80	76	82	78	75	80	77	74	73			
5	90	82	75	71	89	81	75	70	79	74	70	77	73	69	75	72	69	67			
6	86	76	70	65	84	75	69	65	74	68	64	72	68	64	71	67	64	62			
7	81	71	65	60	80	70	64	60	69	64	60	68	63	59	67	62	59	58			
8	77	67	60	56	75	66	60	56	65	59	56	64	59	55	63	58	55	54			
9	73	63	56	52	72	62	56	52	61	56	52	60	55	52	59	55	52	50			
10	69	59	53	49	68	59	53	49	58	52	49	57	52	48	56	52	48	47			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P211851

CATALOG NUMBER: LSR4B30D010BZ EC4B30508027 4LBMH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	191.5	9.1
10°-20°	502.5	23.9
20°-30°	645.8	30.8
30°-40°	485.9	23.1
40°-50°	195.1	9.3
50°-60°	55.5	2.6
60°-70°	17.6	0.8
70°-80°	5.0	0.2
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1339.8	63.8
0°-40°	1825.6	87.0
0°-60°	2076.2	98.9
0°-90°	2099.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2099.2	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2082	
5°	2044	192
15°	1793	502
25°	1426	646
35°	779	486
45°	241	195
55°	57	55
65°	16	18
75°	3	5
85°	0	0
90°	0	



TEST NUMBER: P211851

CATALOG NUMBER: LSR4B30D010BZ EC4B30508027 4LBMH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2081.5
2.5°	2068.9
5°	2043.5
7.5°	1996.0
10°	1935.8
12.5°	1862.9
15°	1793.2
17.5°	1714.0
20°	1628.5
22.5°	1536.6
25°	1425.7
27.5°	1292.6
30°	1137.4
32.5°	963.1
35°	779.4
37.5°	608.3
40°	456.2
42.5°	335.8
45°	240.8
47.5°	164.7
50°	114.1
52.5°	79.2
55°	57.0
57.5°	41.2
60°	31.7
62.5°	22.2
65°	15.8
67.5°	12.7
70°	9.5
72.5°	6.3
75°	3.2
77.5°	3.2
80°	3.2
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)