

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P212091

Luminaire Tested: **LSR4B30D010BZ EC4B30508040 4LBNMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P212091
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR4B30D010BZ EC4B30508040 4LBNMW1
Description: PORTFOLIO 4 INCH CYLINDER
NARROW DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-27.4W DE010-27.95W D5LT-27.65W DMX-27.73W DL2-29.56W
DL3-29.67W DLE-29.73W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2156.6 lumens
Efficiency: N/A
Efficacy: 77.0 lumens/watt
Spacing Criteria (0/90/45): 0.96 / 0.96 / 0.95
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P212091

CATALOG NUMBER: LSR4B30D010BZ EC4B30508040 4LBNMW1

Luminous Intensity Polar Plot





TEST NUMBER: P212091

CATALOG NUMBER: LSR4B30D010BZ EC4B30508040 4LBNMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	105	103	109	106	104	101	102	100	98	98	97	95	95	94	92	90																			
2	105	99	94	90	103	97	93	89	94	90	87	91	88	85	88	85	83	81																			
3	98	90	84	80	96	89	83	79	86	82	78	84	80	76	81	78	75	73																			
4	92	83	76	71	90	82	76	71	80	74	70	78	73	69	76	72	68	67																			
5	87	77	70	65	85	76	69	64	74	68	64	72	67	63	70	66	63	61																			
6	82	71	64	59	80	70	64	59	69	63	58	67	62	58	66	61	58	56																			
7	77	66	59	54	75	65	59	54	64	58	54	63	57	53	62	57	53	52																			
8	73	62	55	50	71	61	55	50	60	54	50	59	53	49	58	53	49	48																			
9	69	58	51	46	68	57	51	46	56	50	46	55	50	46	54	49	46	44																			
10	65	54	48	43	64	54	47	43	53	47	43	52	47	43	51	46	43	41																			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P212091

CATALOG NUMBER: LSR4B30D010BZ EC4B30508040 4LBNMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	169.3	7.8
10°-20°	442.8	20.5
20°-30°	582.8	27.0
30°-40°	453.7	21.0
40°-50°	220.4	10.2
50°-60°	139.2	6.5
60°-70°	89.8	4.2
70°-80°	47.0	2.2
80°-90°	11.6	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1194.9	55.4
0°-40°	1648.6	76.4
0°-60°	2008.2	93.1
0°-90°	2156.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2156.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1840	
5°	1806	169
15°	1579	443
25°	1285	583
35°	726	454
45°	274	220
55°	154	139
65°	89	90
75°	44	47
85°	10	12
90°	0	



TEST NUMBER: P212091

CATALOG NUMBER: LSR4B30D010BZ EC4B30508040 4LBNMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1839.7
2.5°	1829.4
5°	1805.5
7.5°	1764.3
10°	1709.5
12.5°	1647.9
15°	1579.3
17.5°	1507.4
20°	1432.0
22.5°	1360.1
25°	1284.7
27.5°	1188.8
30°	1058.6
32.5°	904.4
35°	726.3
37.5°	561.8
40°	435.1
42.5°	339.2
45°	274.1
47.5°	222.7
50°	195.3
52.5°	174.7
55°	154.2
57.5°	137.0
60°	119.9
62.5°	102.8
65°	89.1
67.5°	78.8
70°	65.1
72.5°	54.8
75°	44.5
77.5°	34.3
80°	24.0
82.5°	17.1
85°	10.3
87.5°	3.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)