

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P212278

Luminaire Tested: **LSR4B40D010BZ EC4B30509027 4LBWLI1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P212278  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR4B40D010BZ EC4B30509027 4LBWL1  
Description: PORTFOLIO 4 INCH CYLINDER  
WIDE DISTRIBUTION WITH SPECULAR CLEAR TRIM  
WATTAGE D010TR-43.02W DE010-42.54W D5LT-42.539W DMX-41.87W DL2-41.57W  
DL3-44.71W DLE-39.33W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3324.4 lumens  
Efficiency: N/A  
Efficacy: 79.5 lumens/watt  
Spacing Criteria (0/90/45): 1.29 / 1.29 / 1.18  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P212278

CATALOG NUMBER: LSR4B40D010BZ EC4B30509027 4LBWLI1

### Luminous Intensity Polar Plot





TEST NUMBER: P212278

CATALOG NUMBER: LSR4B40D010BZ EC4B30509027 4LBWL11

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	96	95	94	92	92	92	92
2	106	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84	84	84	84
3	100	93	87	83	98	92	86	82	89	85	81	86	83	80	84	81	78	77	77	77	77
4	94	86	79	75	92	84	79	74	82	77	73	80	76	72	78	75	72	70	70	70	70
5	88	79	72	68	87	78	72	67	76	71	67	74	70	66	73	69	65	64	64	64	64
6	83	73	66	62	82	72	66	61	71	65	61	69	64	60	68	63	60	58	58	58	58
7	78	68	61	56	77	67	61	56	66	60	56	64	59	55	63	59	55	54	54	54	54
8	74	63	56	52	72	62	56	51	61	55	51	60	55	51	59	54	51	49	49	49	49
9	69	59	52	48	68	58	52	47	57	51	47	56	51	47	55	50	47	45	45	45	45
10	66	55	48	44	65	54	48	44	53	48	44	53	47	44	52	47	43	42	42	42	42

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P212278

CATALOG NUMBER: LSR4B40D010BZ EC4B30509027 4LBWL11

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	199.2	6.0
10°-20°	628.6	18.9
20°-30°	980.7	29.5
30°-40°	954.2	28.7
40°-50°	476.6	14.3
50°-60°	73.8	2.2
60°-70°	8.9	0.3
70°-80°	2.5	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1808.5	54.4
0°-40°	2762.7	83.1
0°-60°	3313.1	99.7
0°-90°	3324.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3324.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2037	
5°	2064	199
15°	2220	629
25°	2155	981
35°	1550	954
45°	598	477
55°	61	74
65°	8	9
75°	4	2
85°	0	0
90°	0	



TEST NUMBER: P212278

CATALOG NUMBER: LSR4B40D010BZ EC4B30509027 4LBWLI1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2037.0
2.5°	2044.6
5°	2063.6
7.5°	2094.1
10°	2132.2
12.5°	2181.6
15°	2219.7
17.5°	2250.2
20°	2254.0
22.5°	2227.3
25°	2155.0
27.5°	2048.4
30°	1915.1
32.5°	1747.6
35°	1549.6
37.5°	1332.6
40°	1104.2
42.5°	860.5
45°	597.8
47.5°	384.5
50°	232.3
52.5°	125.6
55°	60.9
57.5°	26.7
60°	15.2
62.5°	11.4
65°	7.6
67.5°	7.6
70°	3.8
72.5°	3.8
75°	3.8
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)