

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P212446

Luminaire Tested: **LSR4B40D010BZ EC4B30509035 4LBSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P212446
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR4B40D010BZ EC4B30509035 4LBSMW1
Description: PORTFOLIO 4 INCH CYLINDER
SHALLOW DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-43.02W DE010-42.54W D5LT-42.539W DMX-41.87W DL2-41.57W
DL3-44.71W DLE-39.33W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3626.6 lumens
Efficiency: N/A
Efficacy: 86.8 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.34
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 41.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P212446

CATALOG NUMBER: LSR4B40D010BZ EC4B30509035 4LBSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P212446

CATALOG NUMBER: LSR4B40D010BZ EC4B30509035 4LBSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	110	106	102	99	107	104	100	97	99	97	94	96	93	91	92	90	88	86			
2	101	93	87	82	98	92	86	81	88	83	79	85	81	77	82	79	76	74			
3	93	83	75	69	90	81	74	69	78	72	67	76	70	66	73	69	65	63			
4	85	74	66	59	83	72	65	59	70	63	58	68	62	57	66	61	56	54			
5	78	66	58	51	76	65	57	51	63	56	51	61	55	50	59	54	49	47			
6	73	60	51	45	71	59	51	45	57	50	44	55	49	44	54	48	44	42			
7	67	54	46	40	66	54	46	40	52	45	40	51	44	39	49	43	39	37			
8	63	50	41	36	61	49	41	36	48	41	35	46	40	35	45	39	35	33			
9	59	46	38	32	57	45	37	32	44	37	32	43	36	32	42	36	32	30			
10	55	42	34	29	54	42	34	29	41	34	29	40	33	29	39	33	29	27			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P212446

CATALOG NUMBER: LSR4B40D010BZ EC4B30509035 4LBSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	138.4	3.8
10°-20°	394.6	10.9
20°-30°	594.4	16.4
30°-40°	707.2	19.5
40°-50°	705.9	19.5
50°-60°	574.1	15.8
60°-70°	353.2	9.7
70°-80°	136.8	3.8
80°-90°	21.9	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1127.4	31.1
0°-40°	1834.7	50.6
0°-60°	3114.7	85.9
0°-90°	3626.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3626.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1461	
5°	1457	138
15°	1401	395
25°	1294	594
35°	1132	707
45°	918	706
55°	642	574
65°	354	353
75°	125	137
85°	17	22
90°	0	



TEST NUMBER: P212446

CATALOG NUMBER: LSR4B40D010BZ EC4B30509035 4LBSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1461.2
2.5°	1463.3
5°	1456.9
7.5°	1448.3
10°	1437.5
12.5°	1418.2
15°	1401.0
17.5°	1375.2
20°	1347.3
22.5°	1321.5
25°	1293.6
27.5°	1254.9
30°	1216.2
32.5°	1179.7
35°	1132.4
37.5°	1080.8
40°	1033.6
42.5°	975.5
45°	917.5
47.5°	855.2
50°	788.6
52.5°	719.8
55°	642.5
57.5°	567.3
60°	494.2
62.5°	423.3
65°	354.5
67.5°	290.1
70°	229.9
72.5°	174.0
75°	124.6
77.5°	81.7
80°	49.4
82.5°	30.1
85°	17.2
87.5°	8.6
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)