

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P429797

Luminaire Tested: **LAM4B112R209030DE010x1MMS**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P429797
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2007-857-3)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B112R209030DE010x1MMS
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 20 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1189.1 lumens
Efficiency: N/A
Efficacy: 83.2 lumens/watt
Spacing Criteria (0/90/45): 0.34 / 0.34 / 0.33
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P429797

CATALOG NUMBER: LAM4B112R209030DE010x1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P429797

CATALOG NUMBER: LAM4B112R209030DE010x1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	115	113	111	110	113	111	109	108	107	106	105	103	102	101	100	99	99	97	97	97	97
2	112	108	105	103	110	106	104	102	103	101	100	101	99	97	98	97	95	94	94	94	94
3	108	104	100	98	107	103	99	97	100	98	95	98	96	94	96	94	93	91	91	91	91
4	105	100	97	94	104	99	96	93	97	94	92	95	93	91	94	92	90	89	89	89	89
5	103	97	93	90	101	96	93	90	95	92	89	93	91	89	92	90	88	87	87	87	87
6	100	94	90	88	99	94	90	87	92	89	87	91	88	86	90	88	86	85	85	85	85
7	98	92	88	85	97	91	88	85	90	87	85	89	86	84	88	86	84	83	83	83	83
8	96	90	86	83	95	89	86	83	88	85	83	87	85	82	87	84	82	81	81	81	81
9	94	88	84	81	93	87	84	81	86	83	81	86	83	81	85	82	81	80	80	80	80
10	92	86	82	80	91	85	82	80	85	82	79	84	81	79	83	81	79	78	78	78	78

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	4107138
5°	3471604
10°	2039082
15°	730115
20°	241573
25°	96138
30°	45975
35°	26261
40°	18935
45°	15978
50°	18421
55°	14967
60°	7499
65°	6421
70°	7934
75°	8388
80°	6251
85°	6227



TEST NUMBER: P429797

CATALOG NUMBER: LAM4B112R209030DE010x1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	574.0	48.3
10°-20°	447.6	37.6
20°-30°	92.9	7.8
30°-40°	29.3	2.5
40°-50°	18.8	1.6
50°-60°	15.1	1.3
60°-70°	6.0	0.5
70°-80°	4.5	0.4
80°-90°	0.9	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1114.5	93.7
0°-40°	1143.8	96.2
0°-60°	1177.7	99.0
0°-90°	1189.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1189.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	8324	
5°	7010	574
15°	1429	448
25°	177	93
35°	44	29
45°	23	19
55°	17	15
65°	6	6
75°	4	4
85°	1	1
90°	0	



TEST NUMBER: P429797

CATALOG NUMBER: LAM4B112R209030DE010x1MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	8324.5
2.5°	8019.2
5°	7009.6
7.5°	5616.2
10°	4070.1
12.5°	2567.7
15°	1429.4
17.5°	786.1
20°	460.1
22.5°	281.3
25°	176.6
27.5°	116.7
30°	80.7
32.5°	56.7
35°	43.6
37.5°	34.9
40°	29.4
42.5°	25.1
45°	22.9
47.5°	22.9
50°	24.0
52.5°	22.9
55°	17.4
57.5°	12.0
60°	7.6
62.5°	6.5
65°	5.5
67.5°	5.5
70°	5.5
72.5°	5.5
75°	4.4
77.5°	3.3
80°	2.2
82.5°	1.1
85°	1.1
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)