

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P430423

Luminaire Tested: **LAM4B312R309035DE01021MB**

Issue Date: 11/23/2020

Test Information

Test Method: LM-41-14
Report Number: P430423
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2007-857-8)
Test Lab: INNOVATION CENTER (G1)
Issue Date: 11/23/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LAM4B312R309035DE01021MB
Description: PORTFOLIO 4INCH ADJUSTABLE MULTIPLE, 30 DEG TIR OPTIC
Light Source: HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3869.3 lumens
Efficiency: N/A
Efficacy: 94.6 lumens/watt
Spacing Criteria (0/90/45): 0.51 / 0.51 / 0.46
Luminous Opening: Circular (Dia: 0.17' x H: 0')
CIE Type: Direct

Input Watts (W): 40.9
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P430423
CATALOG NUMBER: LAM4B312R309035DE01021MB

Luminous Intensity Polar Plot





TEST NUMBER: P430423

CATALOG NUMBER: LAM4B312R309035DE01021MB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20																																
RC	80									70									50									30									10									0														
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																														
RCR																																																												
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																																										
1	115	113	111	109	112	111	109	107	107	105	104	103	102	101	100	99	98	96	96	95	94	93	92	91	90	89	88	87	85	84	81																													
2	111	107	104	102	109	106	103	100	102	100	98	96	94	92	90	88	86	84	82	80	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50																									
3	107	103	99	96	105	101	98	95	99	96	94	92	90	88	86	84	82	80	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40																						
4	104	98	94	91	102	97	94	91	95	92	90	88	86	84	82	80	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40	38	36	34	32	30																			
5	101	95	91	87	99	94	90	87	92	89	86	84	82	80	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40	38	36	34	32	30	28	26	24	22	20																
6	98	91	87	84	97	91	87	84	89	86	83	81	79	77	75	73	71	69	67	65	63	61	59	57	55	53	51	49	47	45	43	41	39	37	35	33	31	29	27	25	23	21	19	17	15	13	11	9	7	5	3	1								
7	95	88	84	81	94	88	84	81	87	83	81	79	77	75	73	71	69	67	65	63	61	59	57	55	53	51	49	47	45	43	41	39	37	35	33	31	29	27	25	23	21	19	17	15	13	11	9	7	5	3	1									
8	92	86	81	79	91	85	81	78	84	81	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40	38	36	34	32	30	28	26	24	22	20	18	16	14	12	10	8	6	4	2	0										
9	90	83	79	76	89	83	79	76	82	78	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40	38	36	34	32	30	28	26	24	22	20	18	16	14	12	10	8	6	4	2	0											
10	88	81	77	74	87	80	77	74	80	76	74	72	70	68	66	64	62	60	58	56	54	52	50	48	46	44	42	40	38	36	34	32	30	28	26	24	22	20	18	16	14	12	10	8	6	4	2	0												

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	7010677
5°	6857527
10°	5945808
15°	3685205
20°	1350675
25°	451512
30°	221615
35°	110523
40°	68528
45°	43539
50°	31010
55°	25289
60°	21709
65°	17161
70°	21205
75°	20969
80°	20741
85°	20945



TEST NUMBER: P430423

CATALOG NUMBER: LAM4B312R309035DE01021MB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1261.9	32.6
10°-20°	1905.2	49.2
20°-30°	464.5	12.0
30°-40°	127.2	3.3
40°-50°	51.2	1.3
50°-60°	27.4	0.7
60°-70°	16.3	0.4
70°-80°	12.6	0.3
80°-90°	3.0	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3631.6	93.9
0°-40°	3758.8	97.1
0°-60°	3837.4	99.2
0°-90°	3869.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3869.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	14210	
5°	13846	###
15°	7215	1905
25°	829	465
35°	184	127
45°	62	51
55°	29	27
65°	15	16
75°	11	13
85°	4	3
90°	0	



TEST NUMBER: P430423

CATALOG NUMBER: LAM4B312R309035DE01021MB

CANDELA DISTRIBUTION (FULL):

	0°
0°	14209.5
2.5°	14114.0
5°	13846.2
7.5°	13207.6
10°	11868.1
12.5°	9769.0
15°	7214.8
17.5°	4649.6
20°	2572.5
22.5°	1372.5
25°	829.4
27.5°	561.5
30°	389.0
32.5°	264.2
35°	183.5
37.5°	135.8
40°	106.4
42.5°	80.7
45°	62.4
47.5°	51.4
50°	40.4
52.5°	36.7
55°	29.4
57.5°	25.7
60°	22.0
62.5°	18.3
65°	14.7
67.5°	14.7
70°	14.7
72.5°	14.7
75°	11.0
77.5°	11.0
80°	7.3
82.5°	3.7
85°	3.7
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)