

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P843417

Luminaire Tested: **LD4C15DE010B50 EU4C15B50 4LBNLI**

Issue Date: 2/16/2023



**Test Information**

Test Method: LM-79-08  
Report Number: P843417  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P208279)  
Test Lab: INNOVATION CENTER  
Issue Date: 2/16/2023  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LD4C15DE010B50 EU4C15B50 4LBNLI  
Description: 4in Downlight with BioUp LEDs  
Light Source: -  
Ballast/Driver:

**Summary**


Lumens per Lamp: N/A  
Luminaire Lumens: 1183.5 lumens  
Efficiency: N/A  
Efficacy: 69.6 lumens/watt  
Spacing Criteria (0/90/45): 0.48 / 0.48 / 0.54  
Luminous Opening: Circular (Dia: 0.33' x H: 0')  
CIE Type: Direct

Input Watts (W): 17  
Input Voltage (V):  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P843417

CATALOG NUMBER: LD4C15DE010B50 EU4C15B50 4LBNLI

### Luminous Intensity Polar Plot





TEST NUMBER: P843417

CATALOG NUMBER: LD4C15DE010B50 EU4C15B50 4LBNLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95			95																
2	109	105	102	99	107	103	100	98	100	98	95	97	95	93	95	93	92	90			90																
3	105	99	95	92	103	98	94	91	95	92	89	93	90	88	91	89	87	85			85																
4	101	94	89	86	99	93	88	85	91	87	84	89	86	83	87	84	82	81			81																
5	96	89	84	80	95	88	84	80	87	82	79	85	81	79	83	80	78	77			77																
6	92	85	80	76	91	84	79	76	83	78	75	81	78	75	80	77	74	73			73																
7	89	81	76	72	88	80	75	72	79	75	71	78	74	71	77	73	71	69			69																
8	85	77	72	68	84	77	72	68	76	71	68	75	71	68	74	70	67	66			66																
9	82	74	69	65	81	73	68	65	72	68	65	72	68	65	71	67	64	63			63																
10	79	71	66	62	78	70	65	62	69	65	62	69	65	62	68	64	62	61			61																

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	374175
5°	336708
10°	261024
15°	188924
20°	130816
25°	95362
30°	69298
35°	41004
40°	17256
45°	5386
50°	707
55°	386
60°	442
65°	523
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P843417

CATALOG NUMBER: LD4C15DE010B50 EU4C15B50 4LBNLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	240.0	20.3
10°-20°	410.9	34.7
20°-30°	326.6	27.6
30°-40°	172.9	14.6
40°-50°	29.8	2.5
50°-60°	2.2	0.2
60°-70°	1.1	0.1
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	977.5	82.6
0°-40°	1150.4	97.2
0°-60°	1182.4	99.9
0°-90°	1183.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1183.5	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3046	
5°	2730	240
15°	1485	411
25°	704	327
35°	273	173
45°	31	30
55°	2	2
65°	2	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P843417

CATALOG NUMBER: LD4C15DE010B50 EU4C15B50 4LBNLI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	3045.7
2.5°	2967.2
5°	2730.3
7.5°	2420.5
10°	2092.4
12.5°	1775.2
15°	1485.4
17.5°	1215.6
20°	1000.6
22.5°	836.6
25°	703.5
27.5°	596.0
30°	488.5
32.5°	379.2
35°	273.4
37.5°	180.4
40°	107.6
42.5°	62.0
45°	31.0
47.5°	11.0
50°	3.7
52.5°	3.7
55°	1.8
57.5°	1.8
60°	1.8
62.5°	1.8
65°	1.8
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG







— 0°-180°







(END OF REPORT)