

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P762983

Luminaire Tested: LD6D25D010-EU6DR2015309035-6LBS1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P762983
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2310-195-36)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D25D010-EU6DR2015309035-6LBS1B
Description: 6 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 20° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3124.6 lumens
Efficiency: N/A
Efficacy: 124.5 lumens/watt
Spacing Criteria (0/90/45): 0.34 / 0.34 / 0.36
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct

Input Watts (W): 25.1
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P762983
CATALOG NUMBER: LD6D25D010-EU6DR2015309035-6LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P762983

CATALOG NUMBER: LD6D25D010-EU6DR2015309035-6LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	115	113	111	109	113	111	109	108	107	106	104	103	102	101	100	99	98	97	97	98	97																
2	111	108	105	102	109	106	104	101	103	101	99	100	99	97	98	96	95	94	94	98	94																
3	108	103	100	97	106	102	99	96	100	97	95	97	95	93	95	93	92	91	91	98	91																
4	105	99	96	93	103	98	95	92	96	93	91	95	92	90	93	91	89	88	88	93	89																
5	102	96	92	89	100	95	91	89	94	90	88	92	89	87	91	88	86	85	85	91	86																
6	99	93	89	86	98	92	88	86	91	87	85	90	87	84	88	86	84	83	83	88	84																
7	96	90	86	83	95	89	86	83	88	85	82	87	84	82	86	84	82	81	81	86	82																
8	94	87	83	81	93	87	83	80	86	83	80	85	82	80	84	82	80	79	79	84	80																
9	91	85	81	78	91	85	81	78	84	80	78	83	80	78	82	80	78	77	77	82	78																
10	89	83	79	76	88	82	79	76	82	78	76	81	78	76	81	78	76	75	75	81	76																

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	1943104
5°	1753040
10°	983905
15°	500138
20°	211756
25°	97747
30°	51752
35°	27877
40°	14905
45°	8808
50°	5116
55°	2724
60°	1726
65°	1241
70°	511
75°	0
80°	0
85°	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 8808 cd/sqm



TEST NUMBER: P762983

CATALOG NUMBER: LD6D25D010-EU6DR2015309035-6LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1266.2	40.5
10°-20°	1246.8	39.9
20°-30°	407.3	13.0
30°-40°	138.7	4.4
40°-50°	46.6	1.5
50°-60°	14.1	0.4
60°-70°	4.7	0.2
70°-80°	0.2	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2920.3	93.5
0°-40°	3059.0	97.9
0°-60°	3119.7	99.8
0°-90°	3124.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3124.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	17784	
5°	15984	###
15°	4422	1247
25°	811	407
35°	209	139
45°	57	47
55°	14	14
65°	5	5
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P762983

CATALOG NUMBER: LD6D25D010-EU6DR2015309035-6LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	17784.1
0.5°	17784.1
1°	17761.9
1.5°	17717.5
2°	17636.8
2.5°	17529.1
3°	17377.1
3.5°	17164.9
4°	16849.7
4.5°	16466.5
5°	15983.5
5.5°	15348.5
6°	14697.6
6.5°	13951.7
7°	13221.6
7.5°	12366.5
8°	11603.2
8.5°	10835.1
9°	10125.7
9.5°	9474.8
10°	8868.3
12.5°	6367.7
15°	4421.5
17.5°	2888.5
20°	1821.2
22.5°	1179.8
25°	810.8
27.5°	570.1
30°	410.2
32.5°	294.6
35°	209.0
37.5°	145.7
40°	104.5
42.5°	76.0
45°	57.0
47.5°	44.3
50°	30.1
52.5°	19.0
55°	14.3
57.5°	11.1
60°	7.9
62.5°	6.3
65°	4.8



TEST NUMBER: P762983
CATALOG NUMBER: LD6D25D010-EU6DR2015309035-6LBS1B

CANDELA DISTRIBUTION (continued):

	0°
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





67.5°		3.2
70°		1.6

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)