

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P766985

Luminaire Tested: LD6D45BD010-EU6DR6540509050-6LBDP1LI

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P766985
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D45BD010-EU6DR6540509050-6LBDP1LI
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR CLEAR TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 5000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4806.5 lumens
Efficiency: N/A
Efficacy: 124.2 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct


Input Watts (W): 38.7
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P766985
CATALOG NUMBER: LD6D45BD010-EU6DR6540509050-6LBDP1LI

Luminous Intensity Polar Plot





TEST NUMBER: P766985

CATALOG NUMBER: LD6D45BD010-EU6DR6540509050-6LBDP1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93			
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87			
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80			
4	97	89	84	79	95	88	83	79	86	82	78	84	80	77	82	79	76	75			
5	92	83	78	73	90	83	77	73	81	76	72	79	75	72	77	74	71	69			
6	87	78	72	68	86	77	72	68	76	71	67	74	70	67	73	69	66	65			
7	83	73	67	63	81	73	67	63	71	66	62	70	66	62	69	65	62	60			
8	79	69	63	59	77	68	63	59	67	62	58	66	62	58	65	61	58	57			
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53			
10	71	61	56	52	70	61	55	52	60	55	51	59	55	51	59	54	51	50			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	517055
5°	517483
10°	535704
15°	536595
20°	494020
25°	420933
30°	322234
35°	227658
40°	134386
45°	54560
50°	19769
55°	11010
60°	6315
65°	3464
70°	3642
75°	2828
80°	2957
85°	2507

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 54560 cd/sqm



TEST NUMBER: P766985

CATALOG NUMBER: LD6D45BD010-EU6DR6540509050-6LBDP1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	455.7	9.5
10°-20°	1314.4	27.3
20°-30°	1577.1	32.8
30°-40°	1059.8	22.1
40°-50°	317.3	6.6
50°-60°	56.0	1.2
60°-70°	15.9	0.3
70°-80°	7.8	0.2
80°-90°	2.5	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3347.2	69.6
0°-40°	4407.1	91.7
0°-60°	4780.3	99.5
0°-90°	4806.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4806.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4732	
5°	4718	456
15°	4744	1314
25°	3492	1577
35°	1707	1060
45°	353	317
55°	58	56
65°	13	16
75°	7	8
85°	2	2
90°	0	



TEST NUMBER: P766985

CATALOG NUMBER: LD6D45BD010-EU6DR6540509050-6LBDP1LI

CANDELA DISTRIBUTION (FULL):

	0°
0°	4732.3
2.5°	4752.5
5°	4718.2
7.5°	4789.5
10°	4828.5
12.5°	4819.1
15°	4743.8
17.5°	4559.5
20°	4248.8
22.5°	3883.0
25°	3491.6
27.5°	3049.8
30°	2554.1
32.5°	2104.9
35°	1706.8
37.5°	1313.4
40°	942.2
42.5°	615.3
45°	353.1
47.5°	187.0
50°	116.3
52.5°	80.7
55°	57.8
57.5°	41.7
60°	28.9
62.5°	18.8
65°	13.4
67.5°	12.1
70°	11.4
72.5°	8.7
75°	6.7
77.5°	6.1
80°	4.7
82.5°	3.4
85°	2.0
87.5°	1.3
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)