

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P769598

Luminaire Tested: LD6D65D010-EU6DR3555659030-6LBDP1LI

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P769598  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-20)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D65D010-EU6DR3555659030-6LBDP1LI  
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR CLEAR TRIM, WITH 35° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 7941.8 lumens  
Efficiency: N/A  
Efficacy: 109.1 lumens/watt  
Spacing Criteria (0/90/45): 0.6 / 0.6 / 0.54  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct


Input Watts (W): 72.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



Downlight

TEST NUMBER: P769598  
CATALOG NUMBER: LD6D65D010-EU6DR3555659030-6LBDP1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P769598

CATALOG NUMBER: LD6D65D010-EU6DR3555659030-6LBDP1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0													
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100					100														
1	115	112	110	108	112	110	108	107	106	105	103	103	101	100	99	98	98	96					96														
2	110	106	103	101	108	105	102	99	102	99	97	99	97	95	96	95	93	92					92														
3	106	101	97	94	105	100	96	93	97	95	92	95	93	91	93	91	89	88					88														
4	103	97	92	89	101	96	92	89	94	90	88	92	89	87	90	88	86	84					84														
5	99	93	88	85	98	92	87	84	90	86	84	89	85	83	87	84	82	81					81														
6	96	89	84	81	94	88	84	81	87	83	80	85	82	80	84	81	79	78					78														
7	93	85	81	78	91	85	80	77	84	80	77	83	79	77	82	79	76	75					75														
8	90	82	78	74	88	82	77	74	81	77	74	80	76	74	79	76	73	72					72														
9	87	79	75	72	86	79	75	72	78	74	71	77	74	71	77	73	71	70					70														
10	84	77	72	69	83	76	72	69	76	72	69	75	71	69	74	71	69	68					68														

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	2387544
5°	2331450
10°	2101245
15°	1630904
20°	925020
25°	359883
30°	134263
35°	73587
40°	48095
45°	29281
50°	18630
55°	13163
60°	9637
65°	5248
70°	383
75°	0
80°	0
85°	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 29281 cd/sqm



TEST NUMBER: P769598  
 CATALOG NUMBER: LD6D65D010-EU6DR3555659030-6LBDP1LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	1955.0	24.6
10°-20°	3817.1	48.1
20°-30°	1556.8	19.6
30°-40°	372.5	4.7
40°-50°	155.2	2.0
50°-60°	64.3	0.8
60°-70°	20.1	0.3
70°-80°	0.5	0.0
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	7328.8	92.3
0°-40°	7701.4	97.0
0°-60°	7920.9	99.7
0°-90°	7941.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7941.8	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	21852	
5°	21257	###
15°	14418	3817
25°	2985	1557
35°	552	373
45°	190	155
55°	69	64
65°	20	20
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P769598

CATALOG NUMBER: LD6D65D010-EU6DR3555659030-6LBDP1LI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	21851.8
2.5°	21720.7
5°	21257.2
7.5°	20332.4
10°	18939.3
12.5°	16977.8
15°	14418.1
17.5°	11287.6
20°	7955.6
22.5°	5073.0
25°	2985.2
27.5°	1687.4
30°	1064.2
32.5°	747.2
35°	551.7
37.5°	426.6
40°	337.2
42.5°	259.8
45°	189.5
47.5°	141.8
50°	109.6
52.5°	87.0
55°	69.1
57.5°	56.0
60°	44.1
62.5°	32.2
65°	20.3
67.5°	7.2
70°	1.2
72.5°	1.2
75°	0.0
77.5°	0.0
80°	0.0
82.5°	1.2
85°	0.0
87.5°	0.0
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)