

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P759203

Luminaire Tested: LD6D08D010-EU6DR300210IC9040-6LBDP1H

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P759203  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D08D010-EU6DR300210IC9040-6LBDP1H  
Description: 6 INCH ROUND DEEP 45° CUTOFF SEMI-SPECULAR CLEAR TRIM, WITH 30° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 823.6 lumens  
Efficiency: N/A  
Efficacy: 92.5 lumens/watt  
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49  
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')  
CIE Type: Direct

Input Watts (W): 8.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight



TEST NUMBER: P759203

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9040-6LBDP1H

### Luminous Intensity Polar Plot





TEST NUMBER: P759203

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9040-6LBDP1H

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96																			
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92																			
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89																			
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85																			
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82																			
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79																			
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77																			
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74																			
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72																			
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°	45°	90°
0°	202718	202718	202718
5°	196892	196661	196899
10°	170542	169338	170504
15°	111266	110672	110117
20°	55325	57402	55251
25°	27871	31426	27305
30°	11163	12162	9722
35°	5177	4962	4158
40°	2228	2478	2108
45°	1580	1948	1591
50°	536	1429	572
55°	307	587	334
60°	214	260	214
65°	145	145	145
70°	90	67	90
75°	0	30	0
80°	0	0	0
85°	0	0	0

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 22.5°  
 Vertical Angle: 45°  
 Luminance: 1948 cd/sqm



TEST NUMBER: P759203

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9040-6LBDP1H

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	232.9	28.3
10°-20°	375.1	45.5
20°-30°	162.1	19.7
30°-40°	36.9	4.5
40°-50°	12.7	1.5
50°-60°	3.1	0.4
60°-70°	0.8	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	770.0	93.5
0°-40°	807.0	98.0
0°-60°	822.7	99.9
0°-90°	823.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	823.6	100.0

**CANDELA DISTRIBUTION:**

	0°	22.5°	45°	67.5°	90°	Flux
0°	2648	2648	2648	2648	2648	
5°	2562	2560	2560	2565	2563	233
15°	1404	1387	1397	1392	1390	376
25°	330	342	372	334	323	158
35°	55	57	53	53	44	38
45°	15	18	18	18	15	10
55°	2	2	4	3	2	2
65°	1	1	1	1	1	1
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P759203

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9040-6LBDP1H

**CANDELA DISTRIBUTION (FULL):**

	0°	22.5°	45°	67.5°	90°
0°	2648.4	2648.4	2648.4	2648.4	2648.4
2.5°	2630.8	2628.9	2630.0	2631.3	2631.8
5°	2562.5	2560.1	2559.5	2564.9	2562.6
7.5°	2424.8	2421.3	2416.0	2428.1	2439.4
10°	2194.2	2190.3	2178.7	2184.4	2193.7
12.5°	1853.6	1841.0	1840.8	1858.9	1856.5
15°	1404.1	1387.2	1396.6	1392.0	1389.6
17.5°	944.2	937.7	950.2	946.5	930.2
20°	679.2	681.0	704.7	692.8	678.3
22.5°	495.7	501.8	530.0	499.2	487.9
25°	330.0	342.5	372.1	333.7	323.3
27.5°	202.9	208.7	238.7	200.4	194.6
30°	126.3	123.4	137.6	118.1	110.0
32.5°	82.8	79.2	83.7	75.2	68.6
35°	55.4	56.6	53.1	52.7	44.5
37.5°	34.6	39.8	35.1	37.5	28.6
40°	22.3	28.9	24.8	27.4	21.1
42.5°	18.3	22.2	20.4	21.7	18.7
45°	14.6	18.0	18.0	18.0	14.7
47.5°	8.1	12.1	15.5	12.4	8.6
50°	4.5	6.1	12.0	6.4	4.8
52.5°	3.1	3.5	8.2	3.7	3.3
55°	2.3	2.5	4.4	2.6	2.5
57.5°	1.8	1.9	2.3	1.9	1.8
60°	1.4	1.4	1.7	1.5	1.4
62.5°	1.0	1.0	1.1	1.0	1.0
65°	0.8	0.8	0.8	0.8	0.8
67.5°	0.4	0.5	0.5	0.5	0.5
70°	0.4	0.3	0.3	0.3	0.4
72.5°	0.3	0.1	0.1	0.1	0.1
75°	0.0	0.0	0.1	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report







— 0°-180°    - - 45°-225°    - - - 90°-270°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)