

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P759216

Luminaire Tested: LD6D08D010-EU6DR300210IC9050-6LBDP1H

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P759216
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D08D010-EU6DR300210IC9050-6LBDP1H
Description: 6 INCH ROUND DEEP 45° CUTOFF SEMI-SPECULAR CLEAR TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 5000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 813.9 lumens
Efficiency: N/A
Efficacy: 91.4 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct

Input Watts (W): 8.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P759216
CATALOG NUMBER: LD6D08D010-EU6DR300210IC9050-6LBDP1H

Luminous Intensity Polar Plot





TEST NUMBER: P759216

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9050-6LBDP1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0													
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						100													
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96						96													
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92						92													
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89						89													
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85						85													
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82						82													
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79						79													
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77						77													
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74						74													
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72						72													
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69						69													

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	200322	200322	200322
5°	194571	194341	194579
10°	168529	167340	168491
15°	109958	109364	108817
20°	54673	56726	54608
25°	27541	31055	26975
30°	11030	12020	9607
35°	5111	4896	4102
40°	2208	2448	2078
45°	1559	1938	1570
50°	536	1405	572
55°	307	587	334
60°	214	260	214
65°	127	127	127
70°	90	45	90
75°	0	30	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°
 Vertical Angle: 45°
 Luminance: 1938 cd/sqm



TEST NUMBER: P759216

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9050-6LBDP1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	230.1	28.3
10°-20°	370.6	45.5
20°-30°	160.2	19.7
30°-40°	36.5	4.5
40°-50°	12.5	1.5
50°-60°	3.1	0.4
60°-70°	0.8	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	760.9	93.5
0°-40°	797.4	98.0
0°-60°	813.0	99.9
0°-90°	813.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	813.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	2617	2617	2617	2617	2617	
5°	2532	2530	2529	2535	2532	230
15°	1388	1371	1380	1376	1373	372
25°	326	338	368	330	319	156
35°	55	56	52	52	44	37
45°	14	18	18	18	14	10
55°	2	2	4	3	2	2
65°	1	1	1	1	1	1
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P759216

CATALOG NUMBER: LD6D08D010-EU6DR300210IC9050-6LBDP1H

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	2617.1	2617.1	2617.1	2617.1	2617.1
2.5°	2599.8	2597.9	2599.0	2600.3	2600.8
5°	2532.3	2529.9	2529.3	2534.6	2532.4
7.5°	2396.3	2392.8	2387.5	2399.5	2410.6
10°	2168.3	2164.4	2153.0	2158.6	2167.8
12.5°	1831.8	1819.3	1819.1	1837.1	1834.6
15°	1387.6	1370.8	1380.1	1375.6	1373.2
17.5°	933.1	926.7	939.0	935.3	919.2
20°	671.2	672.9	696.4	684.6	670.4
22.5°	489.8	495.8	523.7	493.3	482.1
25°	326.1	338.4	367.7	329.8	319.4
27.5°	200.6	206.2	235.9	198.0	192.3
30°	124.8	121.9	136.0	116.7	108.7
32.5°	81.9	78.3	82.7	74.3	67.8
35°	54.7	55.9	52.4	52.0	43.9
37.5°	34.2	39.3	34.7	37.0	28.2
40°	22.1	28.5	24.5	27.1	20.8
42.5°	18.1	21.9	20.2	21.5	18.5
45°	14.4	17.9	17.9	17.9	14.5
47.5°	8.0	12.0	15.3	12.2	8.5
50°	4.5	6.0	11.8	6.3	4.8
52.5°	3.1	3.5	8.1	3.6	3.2
55°	2.3	2.5	4.4	2.6	2.5
57.5°	1.8	1.9	2.3	1.9	1.8
60°	1.4	1.4	1.7	1.5	1.4
62.5°	1.0	1.0	1.1	1.0	1.0
65°	0.7	0.7	0.7	0.7	0.7
67.5°	0.4	0.5	0.5	0.5	0.5
70°	0.4	0.2	0.2	0.2	0.4
72.5°	0.2	0.1	0.1	0.1	0.1
75°	0.0	0.0	0.1	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)