

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P773971

Luminaire Tested: LD6D90BD010-EU6DR6570959030-6LBS1MW

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P773971  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D90BD010-EU6DR6570959030-6LBS1MW  
Description: 6 INCH ROUND SHALLOW MATTE WHITE TRIM, WITH 65° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 9567.2 lumens  
Efficiency: N/A  
Efficacy: 96.7 lumens/watt  
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96  
Luminous Opening: Circular (Dia: 0.48' x H: 0')  
CIE Type: Direct

Input Watts (W): 98.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight

TEST NUMBER: P773971

CATALOG NUMBER: LD6D90BD010-EU6DR6570959030-6LBS1MW

### Luminous Intensity Polar Plot





TEST NUMBER: P773971

CATALOG NUMBER: LD6D90BD010-EU6DR6570959030-6LBS1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93																			
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85																			
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78																			
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72																			
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66																			
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61																			
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56																			
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52																			
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49																			
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	507337
5°	506056
10°	505621
15°	490038
20°	446115
25°	388763
30°	323343
35°	256202
40°	184915
45°	116823
50°	60895
55°	32370
60°	16996
65°	9356
70°	3928
75°	4310
80°	2993
85°	2546

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 116823 cd/sqm



TEST NUMBER: P773971

CATALOG NUMBER: LD6D90BD010-EU6DR6570959030-6LBS1MW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	821.5	8.6
10°-20°	2249.5	23.5
20°-30°	2749.7	28.7
30°-40°	2231.0	23.3
40°-50°	1111.8	11.6
50°-60°	310.1	3.2
60°-70°	70.5	0.7
70°-80°	18.3	0.2
80°-90°	4.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5820.7	60.8
0°-40°	8051.7	84.2
0°-60°	9473.6	99.0
0°-90°	9567.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	9567.2	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	8687	
5°	8632	821
15°	8105	2250
25°	6033	2750
35°	3593	2231
45°	1414	1112
55°	318	310
65°	68	70
75°	19	18
85°	4	5
90°	0	



TEST NUMBER: P773971

CATALOG NUMBER: LD6D90BD010-EU6DR6570959030-6LBS1MW

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	8686.7
2.5°	8680.3
5°	8631.8
7.5°	8603.7
10°	8525.8
12.5°	8367.5
15°	8104.6
17.5°	7693.5
20°	7177.8
22.5°	6621.3
25°	6032.8
27.5°	5403.5
30°	4794.6
32.5°	4193.3
35°	3593.4
37.5°	2994.7
40°	2425.4
42.5°	1891.8
45°	1414.4
47.5°	985.5
50°	670.2
52.5°	462.1
55°	317.9
57.5°	214.5
60°	145.5
62.5°	100.8
65°	67.7
67.5°	34.5
70°	23.0
72.5°	21.7
75°	19.1
77.5°	12.8
80°	8.9
82.5°	6.4
85°	3.8
87.5°	2.6
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)