

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P773980

Luminaire Tested: LD6D90BD010-EU6DR6570959035-6LBDP1MW

Issue Date: 2/5/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P773980  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/5/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D90BD010-EU6DR6570959035-6LBDP1MW  
Description: 6 INCH ROUND DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 65° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 8339.4 lumens  
Efficiency: N/A  
Efficacy: 84.3 lumens/watt  
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct

Input Watts (W): 98.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight

TEST NUMBER: P773980

CATALOG NUMBER: LD6D90BD010-EU6DR6570959035-6LBDP1MW

### Luminous Intensity Polar Plot





TEST NUMBER: P773980

CATALOG NUMBER: LD6D90BD010-EU6DR6570959035-6LBDP1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93																			
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87																			
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80																			
4	97	89	84	79	95	88	83	79	86	82	78	84	80	77	82	79	76	75																			
5	92	83	78	73	90	83	77	73	81	76	72	79	75	72	77	74	71	69																			
6	87	78	72	68	86	77	72	68	76	71	67	74	70	67	73	69	66	65																			
7	83	73	67	63	81	73	67	63	71	66	62	70	66	62	69	65	62	60																			
8	79	69	63	59	77	68	63	59	67	62	58	66	62	58	65	61	58	57																			
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53																			
10	71	61	56	52	70	61	55	52	60	55	51	59	55	51	59	54	51	50																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	897107
5°	897847
10°	929464
15°	931005
20°	857140
25°	730328
30°	559093
35°	394986
40°	233157
45°	94658
50°	34319
55°	19106
60°	10970
65°	6024
70°	6325
75°	4939
80°	5160
85°	4388

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 94658 cd/sqm



TEST NUMBER: P773980

CATALOG NUMBER: LD6D90BD010-EU6DR6570959035-6LBDP1MW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	790.6	9.5
10°-20°	2280.6	27.3
20°-30°	2736.3	32.8
30°-40°	1838.9	22.1
40°-50°	550.5	6.6
50°-60°	97.1	1.2
60°-70°	27.6	0.3
70°-80°	13.6	0.2
80°-90°	4.3	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5807.5	69.6
0°-40°	7646.3	91.7
0°-60°	8294.0	99.5
0°-90°	8339.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8339.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	8211	
5°	8186	791
15°	8231	2281
25°	6058	2736
35°	2961	1839
45°	613	550
55°	100	97
65°	23	28
75°	12	14
85°	4	4
90°	0	



TEST NUMBER: P773980

CATALOG NUMBER: LD6D90BD010-EU6DR6570959035-6LBDP1MW

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	8210.7
2.5°	8245.7
5°	8186.2
7.5°	8309.9
10°	8377.6
12.5°	8361.2
15°	8230.6
17.5°	7910.8
20°	7371.8
22.5°	6737.1
25°	6058.0
27.5°	5291.4
30°	4431.5
32.5°	3652.1
35°	2961.3
37.5°	2278.7
40°	1634.7
42.5°	1067.6
45°	612.6
47.5°	324.4
50°	201.9
52.5°	140.0
55°	100.3
57.5°	72.3
60°	50.2
62.5°	32.7
65°	23.3
67.5°	21.0
70°	19.8
72.5°	15.2
75°	11.7
77.5°	10.5
80°	8.2
82.5°	5.8
85°	3.5
87.5°	2.3
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)