

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P761809

Luminaire Tested: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW

Issue Date: 2/5/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P761809  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-73)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/5/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW  
Description: 6 INCH SQAURE DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 70° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1159.7 lumens  
Efficiency: N/A  
Efficacy: 73.4 lumens/watt  
Spacing Criteria (0/90/45): 0.88 / 0.88 / 0.82  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct

Input Watts (W): 15.8  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight



TEST NUMBER: P761809

CATALOG NUMBER: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW

### Luminous Intensity Polar Plot





TEST NUMBER: P761809

CATALOG NUMBER: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	106	103	110	107	104	102	103	101	99	99	97	96	95	94	93	91																			
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	85	83																			
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	78	76																			
4	94	86	80	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70																			
5	89	80	74	69	87	79	73	69	77	72	68	75	71	67	74	70	67	65																			
6	85	75	68	64	83	74	68	64	73	67	63	71	66	63	70	66	62	61																			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57																			
8	77	66	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55	53																			
9	73	63	57	52	72	62	56	52	61	56	52	60	55	52	60	55	52	50																			
10	70	59	53	49	69	59	53	49	58	53	49	57	52	49	57	52	49	48																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	142465
5°	138227
10°	134378
15°	132616
20°	123831
25°	93033
30°	65769
35°	23289
40°	12252
45°	13057
50°	13513
55°	13753
60°	13854
65°	13547
70°	12778
75°	11862
80°	10508
85°	8525

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 60°  
 Luminance: 13854 cd/sqm



TEST NUMBER: P761809

CATALOG NUMBER: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	118.9	10.2
10°-20°	326.1	28.1
20°-30°	359.1	31.0
30°-40°	137.2	11.8
40°-50°	64.8	5.6
50°-60°	64.4	5.6
60°-70°	51.5	4.4
70°-80°	29.6	2.6
80°-90°	8.0	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	804.1	69.3
0°-40°	941.3	81.2
0°-60°	1070.5	92.3
0°-90°	1159.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1159.7	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1304	
5°	1260	119
15°	1172	326
25°	772	359
35°	175	137
45°	84	65
55°	72	64
65°	52	52
75°	28	30
85°	7	8
90°	0	



TEST NUMBER: P761809

CATALOG NUMBER: LD6D15D010-EU6DR700215IC9030-6LBSQW1MW

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	1303.9
2.5°	1290.2
5°	1260.3
7.5°	1235.3
10°	1211.2
12.5°	1190.8
15°	1172.4
17.5°	1128.0
20°	1065.0
22.5°	929.2
25°	771.7
27.5°	671.8
30°	521.3
32.5°	336.7
35°	174.6
37.5°	94.4
40°	85.9
42.5°	85.3
45°	84.5
47.5°	82.6
50°	79.5
52.5°	76.0
55°	72.2
57.5°	68.1
60°	63.4
62.5°	58.0
65°	52.4
67.5°	46.2
70°	40.0
72.5°	33.9
75°	28.1
77.5°	22.1
80°	16.7
82.5°	11.7
85°	6.8
87.5°	2.7
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)