

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P758133

Luminaire Tested: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P758133
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB
Description: 6 INCH SQAURE SHALLOW CAST MATTE BLACK TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2400K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 514.1 lumens
Efficiency: N/A
Efficacy: 68.5 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct

Input Watts (W): 7.5
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight



TEST NUMBER: P758133

CATALOG NUMBER: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB

Luminous Intensity Polar Plot





TEST NUMBER: P758133

CATALOG NUMBER: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0													
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						100													
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96						96													
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92						92													
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89						89													
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85						85													
5	100	94	89	86	98	93	89	86	91	88	85	90	87	84	88	86	83	82						82													
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79						79													
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77						77													
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74						74													
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72						72													
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69						69													

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	126534	126534	126534
5°	122907	122761	122907
10°	106451	105705	106428
15°	69457	69077	68736
20°	34537	35832	34488
25°	17398	19619	17043
30°	6965	7592	6063
35°	3224	3093	2588
40°	1399	1549	1309
45°	985	1223	996
50°	345	881	357
55°	187	374	200
60°	138	153	138
65°	91	91	91
70°	45	45	45
75°	0	30	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°
 Vertical Angle: 45°
 Luminance: 1223 cd/sqm



TEST NUMBER: P758133

CATALOG NUMBER: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	145.4	28.3
10°-20°	234.1	45.5
20°-30°	101.2	19.7
30°-40°	23.1	4.5
40°-50°	7.9	1.5
50°-60°	1.9	0.4
60°-70°	0.5	0.1
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	480.7	93.5
0°-40°	503.7	98.0
0°-60°	513.5	99.9
0°-90°	514.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	514.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	1653	1653	1653	1653	1653	
5°	1600	1598	1598	1601	1600	145
15°	876	866	872	869	867	235
25°	206	214	232	208	202	99
35°	34	35	33	33	28	23
45°	9	11	11	11	9	6
55°	1	2	3	2	2	1
65°	0	0	0	0	0	0
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P758133

CATALOG NUMBER: LD6D05D010-EU6DR300210IC9024-6LBCSSQMB

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	1653.1	1653.1	1653.1	1653.1	1653.1
2.5°	1642.2	1641.0	1641.7	1642.5	1642.8
5°	1599.6	1598.0	1597.7	1601.0	1599.6
7.5°	1513.6	1511.4	1508.1	1515.6	1522.7
10°	1369.6	1367.2	1360.0	1363.6	1369.3
12.5°	1157.1	1149.2	1149.0	1160.4	1158.9
15°	876.5	865.9	871.7	868.9	867.4
17.5°	589.4	585.3	593.1	590.8	580.6
20°	424.0	425.1	439.9	432.5	423.4
22.5°	309.4	313.2	330.8	311.6	304.5
25°	206.0	213.8	232.3	208.3	201.8
27.5°	126.7	130.3	149.0	125.1	121.5
30°	78.8	77.0	85.9	73.7	68.6
32.5°	51.7	49.4	52.3	46.9	42.9
35°	34.5	35.3	33.1	32.9	27.7
37.5°	21.6	24.8	21.9	23.4	17.9
40°	14.0	18.0	15.5	17.1	13.1
42.5°	11.5	13.9	12.7	13.6	11.7
45°	9.1	11.3	11.3	11.3	9.2
47.5°	5.0	7.6	9.7	7.7	5.3
50°	2.9	3.8	7.4	4.0	3.0
52.5°	1.9	2.2	5.1	2.3	2.0
55°	1.4	1.5	2.8	1.6	1.5
57.5°	1.1	1.2	1.4	1.2	1.1
60°	0.9	0.9	1.0	1.0	0.9
62.5°	0.6	0.6	0.7	0.6	0.6
65°	0.5	0.5	0.5	0.5	0.5
67.5°	0.2	0.3	0.3	0.3	0.3
70°	0.2	0.2	0.2	0.2	0.2
72.5°	0.2	0.1	0.1	0.1	0.1
75°	0.0	0.0	0.1	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)