

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P769202

Luminaire Tested: LD6D60D010-EU6DR6055659027-6LBSQW1MW

Issue Date: 2/5/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P769202  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-57)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/5/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LD6D60D010-EU6DR6055659027-6LBSQW1MW  
Description: 6 INCH SQAURE DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 60° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 6264.9 lumens  
Efficiency: N/A  
Efficacy: 97.3 lumens/watt  
Spacing Criteria (0/90/45): 0.91 / 0.91 / 0.83  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct


Input Watts (W): 64.4  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



TEST NUMBER: P769202

CATALOG NUMBER: LD6D60D010-EU6DR6055659027-6LBSQW1MW

### Luminous Intensity Polar Plot





TEST NUMBER: P769202

CATALOG NUMBER: LD6D60D010-EU6DR6055659027-6LBSQW1MW

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	108	105	111	108	106	104	104	102	100	100	99	97	97	96	95	93																			
2	107	102	98	95	105	101	97	94	97	94	92	94	92	90	92	90	88	86																			
3	102	96	90	86	100	94	89	86	91	88	84	89	86	83	87	84	82	80																			
4	97	89	84	80	95	88	83	79	86	82	78	84	80	77	82	79	76	75																			
5	92	84	78	74	91	83	78	74	81	77	73	80	76	72	78	75	72	70																			
6	88	79	73	69	87	78	73	69	77	72	68	75	71	68	74	70	67	66																			
7	84	75	69	65	83	74	68	64	73	68	64	72	67	64	71	67	63	62																			
8	80	71	65	61	79	70	65	61	69	64	60	68	64	60	67	63	60	59																			
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55																			
10	73	64	58	54	72	63	58	54	62	58	54	62	57	54	61	57	54	53																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	812933
5°	832928
10°	842992
15°	803060
20°	708055
25°	572689
30°	387372
35°	194112
40°	31493
45°	30826
50°	31429
55°	31907
60°	32800
65°	33558
70°	34342
75°	34743
80°	33537
85°	27956

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 75°  
 Luminance: 34743 cd/sqm



TEST NUMBER: P769202

CATALOG NUMBER: LD6D60D010-EU6DR6055659027-6LBSQW1MW

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	725.8	11.6
10°-20°	1963.8	31.3
20°-30°	2112.8	33.7
30°-40°	918.4	14.7
40°-50°	154.3	2.5
50°-60°	150.0	2.4
60°-70°	128.3	2.0
70°-80°	85.9	1.4
80°-90°	25.7	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4802.4	76.7
0°-40°	5720.8	91.3
0°-60°	6025.1	96.2
0°-90°	6264.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6264.9	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	7440	
5°	7594	726
15°	7100	1964
25°	4750	2113
35°	1455	918
45°	200	154
55°	168	150
65°	130	128
75°	82	86
85°	22	26
90°	0	



TEST NUMBER: P769202

CATALOG NUMBER: LD6D60D010-EU6DR6055659027-6LBSQW1MW

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	7440.3
2.5°	7649.5
5°	7594.3
7.5°	7611.7
10°	7598.2
12.5°	7441.3
15°	7099.5
17.5°	6640.5
20°	6089.6
22.5°	5499.9
25°	4750.4
27.5°	3799.6
30°	3070.4
32.5°	2366.5
35°	1455.3
37.5°	622.6
40°	220.8
42.5°	203.3
45°	199.5
47.5°	192.7
50°	184.9
52.5°	176.2
55°	167.5
57.5°	158.8
60°	150.1
62.5°	140.4
65°	129.8
67.5°	119.1
70°	107.5
72.5°	94.9
75°	82.3
77.5°	67.8
80°	53.3
82.5°	37.8
85°	22.3
87.5°	7.7
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)