

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P771685

Luminaire Tested: LD6D75BD010-EU6DR7070959024-6LBSQW1MW

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P771685
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-73)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D75BD010-EU6DR7070959024-6LBSQW1MW
Description: 6 INCH SQAURE DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 70° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2400K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6070.6 lumens
Efficiency: N/A
Efficacy: 83.8 lumens/watt
Spacing Criteria (0/90/45): 0.88 / 0.88 / 0.82
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct


Input Watts (W): 72.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P771685

CATALOG NUMBER: LD6D75BD010-EU6DR7070959024-6LBSQW1MW

Luminous Intensity Polar Plot





TEST NUMBER: P771685

CATALOG NUMBER: LD6D75BD010-EU6DR7070959024-6LBSQW1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	106	103	110	107	104	102	103	101	99	99	97	96	95	94	93	91																			
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	85	83																			
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	78	76																			
4	94	86	80	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70																			
5	89	80	74	69	87	79	73	69	77	72	68	75	71	67	74	70	67	65																			
6	85	75	68	64	83	74	68	64	73	67	63	71	66	63	70	66	62	61																			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57																			
8	77	66	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55	53																			
9	73	63	57	52	72	62	56	52	61	56	52	60	55	52	60	55	52	50																			
10	70	59	53	49	69	59	53	49	58	53	49	57	52	49	57	52	49	48																			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	745716
5°	723557
10°	703388
15°	694164
20°	648198
25°	486961
30°	344237
35°	121939
40°	64112
45°	68297
50°	70711
55°	72043
60°	72484
65°	70967
70°	66958
75°	62056
80°	55056
85°	44754

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 57.5°
 Luminance: 72515 cd/sqm



TEST NUMBER: P771685

CATALOG NUMBER: LD6D75BD010-EU6DR7070959024-6LBSQW1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	622.2	10.3
10°-20°	1706.8	28.1
20°-30°	1879.8	31.0
30°-40°	718.2	11.8
40°-50°	339.1	5.6
50°-60°	337.1	5.6
60°-70°	270.0	4.4
70°-80°	155.1	2.6
80°-90°	42.2	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4208.8	69.3
0°-40°	4927.1	81.2
0°-60°	5603.3	92.3
0°-90°	6070.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6070.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6825	
5°	6597	622
15°	6137	1707
25°	4039	1880
35°	914	718
45°	442	339
55°	378	337
65°	274	270
75°	147	155
85°	36	42
90°	0	



TEST NUMBER: P771685

CATALOG NUMBER: LD6D75BD010-EU6DR7070959024-6LBSQW1MW

CANDELA DISTRIBUTION (FULL):

	0°
0°	6825.1
2.5°	6753.8
5°	6597.1
7.5°	6466.3
10°	6339.9
12.5°	6232.9
15°	6136.8
17.5°	5904.4
20°	5574.8
22.5°	4863.8
25°	4039.3
27.5°	3516.3
30°	2728.5
32.5°	1762.5
35°	914.2
37.5°	493.8
40°	449.5
42.5°	446.3
45°	442.0
47.5°	432.2
50°	416.0
52.5°	397.7
55°	378.2
57.5°	356.6
60°	331.7
62.5°	303.7
65°	274.5
67.5°	242.1
70°	209.6
72.5°	177.2
75°	147.0
77.5°	115.6
80°	87.5
82.5°	61.6
85°	35.7
87.5°	14.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)