

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P771623

Luminaire Tested: LD6D75BD010-EU6DR6570959030-6LBCSSQMW

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P771623
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LD6D75BD010-EU6DR6570959030-6LBCSSQMW
Description: 6 INCH SQAURE SHALLOW CAST MATTE WHITE TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3000K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 7647.3 lumens
Efficiency: N/A
Efficacy: 105.6 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct


Input Watts (W): 72.4
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



TEST NUMBER: P771623

CATALOG NUMBER: LD6D75BD010-EU6DR6570959030-6LBCSSQMW

Luminous Intensity Polar Plot





TEST NUMBER: P771623

CATALOG NUMBER: LD6D75BD010-EU6DR6570959030-6LBCSSQMW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93			93																
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85																
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78			78																
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72			72																
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66			66																
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61																
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56																
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52			52																
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49			49																
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46			46																

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	405527
5°	404508
10°	404163
15°	391705
20°	356598
25°	310750
30°	258460
35°	204789
40°	147808
45°	93383
50°	48674
55°	25873
60°	13585
65°	7476
70°	3142
75°	3453
80°	2388
85°	2077

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 93383 cd/sqm



TEST NUMBER: P771623

CATALOG NUMBER: LD6D75BD010-EU6DR6570959030-6LBCSSQMW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	656.6	8.6
10°-20°	1798.1	23.5
20°-30°	2197.9	28.7
30°-40°	1783.3	23.3
40°-50°	888.7	11.6
50°-60°	247.9	3.2
60°-70°	56.3	0.7
70°-80°	14.6	0.2
80°-90°	3.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4652.7	60.8
0°-40°	6436.0	84.2
0°-60°	7572.6	99.0
0°-90°	7647.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7647.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	6944	
5°	6900	657
15°	6478	1798
25°	4822	2198
35°	2872	1783
45°	1131	889
55°	254	248
65°	54	56
75°	15	15
85°	3	4
90°	0	



TEST NUMBER: P771623

CATALOG NUMBER: LD6D75BD010-EU6DR6570959030-6LBCSSQMW

CANDELA DISTRIBUTION (FULL):

	0°
0°	6943.5
2.5°	6938.4
5°	6899.7
7.5°	6877.2
10°	6815.0
12.5°	6688.4
15°	6478.3
17.5°	6149.7
20°	5737.5
22.5°	5292.6
25°	4822.2
27.5°	4319.2
30°	3832.5
32.5°	3351.9
35°	2872.3
37.5°	2393.8
40°	1938.7
42.5°	1512.2
45°	1130.6
47.5°	787.7
50°	535.7
52.5°	369.4
55°	254.1
57.5°	171.4
60°	116.3
62.5°	80.6
65°	54.1
67.5°	27.5
70°	18.4
72.5°	17.3
75°	15.3
77.5°	10.2
80°	7.1
82.5°	5.1
85°	3.1
87.5°	2.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)