

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204509

Luminaire Tested: **LD6B40D010 EU6B30509730 6LBSB1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P204509  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LD6B40D010 EU6B30509730 6LBSB1  
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT  
SHALLOW DISTRIBUTION WITH SPECULAR BLACK TRIM  
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57  
W DL3-44.71 W DLE-39.33 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2854.9 lumens  
Efficiency: N/A  
Efficacy: 68.3 lumens/watt  
Spacing Criteria (0/90/45): 1.2 / 1.2 / 1.3  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P204509

CATALOG NUMBER: LD6B40D010 EU6B30509730 6LBSB1

### Luminous Intensity Polar Plot





TEST NUMBER: P204509

CATALOG NUMBER: LD6B40D010 EU6B30509730 6LBSB1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	107	103	100	108	105	101	98	100	98	95	97	94	93	93	91	90	88			88
2	102	95	89	84	100	93	88	83	90	85	81	86	83	79	84	80	78	76			76
3	94	84	77	72	91	83	76	71	80	74	70	77	73	68	75	71	67	65			65
4	86	76	68	62	84	74	67	61	72	65	60	70	64	60	68	63	59	57			57
5	80	68	60	54	78	67	59	53	65	58	53	63	57	52	61	56	52	50			50
6	74	62	53	47	72	61	53	47	59	52	47	57	51	46	56	50	46	44			44
7	69	56	48	42	67	55	48	42	54	47	42	52	46	41	51	45	41	39			39
8	64	51	43	38	63	51	43	38	49	42	37	48	42	37	47	41	37	35			35
9	60	47	39	34	59	47	39	34	46	39	34	45	38	34	44	38	34	32			32
10	56	44	36	31	55	43	36	31	42	36	31	41	35	31	40	35	31	29			29

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P204509

CATALOG NUMBER: LD6B40D010 EU6B30509730 6LBSB1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	118.9	4.2
10°-20°	337.3	11.8
20°-30°	501.7	17.6
30°-40°	583.8	20.4
40°-50°	569.1	19.9
50°-60°	437.7	15.3
60°-70°	242.0	8.5
70°-80°	64.1	2.2
80°-90°	0.5	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	957.8	33.6
0°-40°	1541.6	54.0
0°-60°	2548.3	89.3
0°-90°	2854.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2854.9	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1259	
5°	1252	119
15°	1194	337
25°	1089	502
35°	937	584
45°	738	569
55°	488	438
65°	242	242
75°	54	64
85°	0	0
90°	0	



TEST NUMBER: P204509

CATALOG NUMBER: LD6B40D010 EU6B30509730 6LBSB1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1259.4
2.5°	1259.4
5°	1252.1
7.5°	1241.3
10°	1234.0
12.5°	1212.3
15°	1194.2
17.5°	1176.1
20°	1150.8
22.5°	1125.5
25°	1089.3
27.5°	1053.1
30°	1016.9
32.5°	977.1
35°	937.3
37.5°	886.6
40°	843.2
42.5°	796.2
45°	738.3
47.5°	684.0
50°	622.4
52.5°	557.3
55°	488.5
57.5°	423.4
60°	361.9
62.5°	300.4
65°	242.5
67.5°	188.2
70°	137.5
72.5°	94.1
75°	54.3
77.5°	25.3
80°	3.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)