

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204605

Luminaire Tested: **LD6B40D010 EU6B30508050 6LBSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204605
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B40D010 EU6B30508050 6LB5MW1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57
W DL3-44.71 W DLE-39.33 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4697.3 lumens
Efficiency: N/A
Efficacy: 112.4 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.34
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 41.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204605

CATALOG NUMBER: LD6B40D010 EU6B30508050 6LBSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204605

CATALOG NUMBER: LD6B40D010 EU6B30508050 6LBSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	110	106	102	99	107	104	100	97	99	97	94	96	93	91	92	90	88	86				86
2	101	93	87	82	98	92	86	81	88	83	79	85	81	77	82	79	76	74				74
3	93	83	75	69	90	81	74	69	78	72	67	76	70	66	73	69	65	63				63
4	85	74	66	59	83	72	65	59	70	63	58	68	62	57	66	61	56	54				54
5	78	66	58	51	76	65	57	51	63	56	51	61	55	50	59	54	49	47				47
6	73	60	51	45	71	59	51	45	57	50	44	55	49	44	54	48	44	42				42
7	67	54	46	40	66	54	46	40	52	45	40	51	44	39	49	43	39	37				37
8	63	50	41	36	61	49	41	36	48	41	35	46	40	35	45	39	35	33				33
9	59	46	38	32	57	45	37	32	44	37	32	43	36	32	42	36	32	30				30
10	55	42	34	29	54	42	34	29	41	34	29	40	33	29	39	33	29	27				27

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204605

CATALOG NUMBER: LD6B40D010 EU6B30508050 6LBSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	179.3	3.8
10°-20°	511.2	10.9
20°-30°	769.8	16.4
30°-40°	916.0	19.5
40°-50°	914.3	19.5
50°-60°	743.6	15.8
60°-70°	457.4	9.7
70°-80°	177.2	3.8
80°-90°	28.4	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1460.3	31.1
0°-40°	2376.3	50.6
0°-60°	4034.3	85.9
0°-90°	4697.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4697.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1893	
5°	1887	179
15°	1815	511
25°	1676	770
35°	1467	916
45°	1188	914
55°	832	744
65°	459	457
75°	161	177
85°	22	28
90°	0	



TEST NUMBER: P204605

CATALOG NUMBER: LD6B40D010 EU6B30508050 6LBSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1892.6
2.5°	1895.4
5°	1887.0
7.5°	1875.9
10°	1862.0
12.5°	1836.9
15°	1814.6
17.5°	1781.2
20°	1745.1
22.5°	1711.7
25°	1675.5
27.5°	1625.4
30°	1575.3
32.5°	1528.0
35°	1466.7
37.5°	1399.9
40°	1338.7
42.5°	1263.6
45°	1188.4
47.5°	1107.7
50°	1021.4
52.5°	932.4
55°	832.2
57.5°	734.8
60°	640.1
62.5°	548.3
65°	459.2
67.5°	375.7
70°	297.8
72.5°	225.4
75°	161.4
77.5°	105.8
80°	64.0
82.5°	39.0
85°	22.3
87.5°	11.1
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)