

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204103

Luminaire Tested: **LD6B50D010TE EU6B30509024 6LBNMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204103
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30509024 6LBNMW1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
NARROW DISTRIBUTION WITH MATTE WHITE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2787.8 lumens
Efficiency: N/A
Efficacy: 47.4 lumens/watt
Spacing Criteria (0/90/45): 0.99 / 0.99 / 0.97
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204103

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBNMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204103

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBNMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	112	108	105	103	109	106	103	101	102	100	98	98	97	95	95	93	92	90			
2	105	99	94	90	102	97	92	89	94	90	87	91	87	85	88	85	83	81			
3	98	90	84	79	96	89	83	79	86	81	77	84	80	76	81	78	75	73			
4	92	83	76	71	90	82	76	71	80	74	70	77	73	69	75	71	68	66			
5	87	77	70	65	85	76	69	64	74	68	64	72	67	63	70	66	62	61			
6	81	71	64	59	80	70	63	59	68	63	58	67	62	58	66	61	57	56			
7	77	66	59	54	75	65	59	54	64	58	54	63	57	53	61	57	53	51			
8	72	61	55	50	71	61	54	50	60	54	49	59	53	49	58	53	49	47			
9	69	58	51	46	67	57	51	46	56	50	46	55	50	46	54	49	46	44			
10	65	54	47	43	64	54	47	43	53	47	43	52	46	43	51	46	43	41			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204103

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBNMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	212.3	7.6
10°-20°	562.7	20.2
20°-30°	751.3	26.9
30°-40°	606.1	21.7
40°-50°	290.5	10.4
50°-60°	172.2	6.2
60°-70°	114.5	4.1
70°-80°	61.3	2.2
80°-90°	16.9	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1526.3	54.8
0°-40°	2132.5	76.5
0°-60°	2595.1	93.1
0°-90°	2787.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2787.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2286	
5°	2260	212
15°	2003	563
25°	1644	751
35°	970	606
45°	359	290
55°	190	172
65°	115	114
75°	58	61
85°	13	17
90°	0	



TEST NUMBER: P204103

CATALOG NUMBER: LD6B50D010TE EU6B30509024 6LBNMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2286.3
2.5°	2286.3
5°	2259.7
7.5°	2215.4
10°	2153.4
12.5°	2086.9
15°	2002.7
17.5°	1923.0
20°	1834.4
22.5°	1741.3
25°	1643.8
27.5°	1541.9
30°	1395.7
32.5°	1191.9
35°	970.4
37.5°	766.5
40°	593.7
42.5°	460.8
45°	358.9
47.5°	283.6
50°	239.3
52.5°	212.7
55°	190.5
57.5°	172.8
60°	150.6
62.5°	132.9
65°	115.2
67.5°	97.5
70°	84.2
72.5°	70.9
75°	57.6
77.5°	44.3
80°	35.4
82.5°	26.6
85°	13.3
87.5°	4.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)