

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204621

Luminaire Tested: **LD6B50D010TE EU6B30509030 6LBSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204621
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B50D010TE EU6B30509030 6LB5MW1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH MATTE WHITE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4957.8 lumens
Efficiency: N/A
Efficacy: 84.4 lumens/watt
Spacing Criteria (0/90/45): 1.24 / 1.24 / 1.34
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.77
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204621

CATALOG NUMBER: LD6B50D010TE EU6B30509030 6LBSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204621

CATALOG NUMBER: LD6B50D010TE EU6B30509030 6LBSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	110	106	102	99	107	104	100	97	99	97	94	96	93	91	92	90	88	86				86
2	101	93	87	82	98	92	86	81	88	83	79	85	81	77	82	79	76	74				74
3	93	83	75	69	90	81	74	69	78	72	67	76	70	66	73	69	65	63				63
4	85	74	66	59	83	72	65	59	70	63	58	68	62	57	66	61	56	54				54
5	78	66	58	51	76	65	57	51	63	56	51	61	55	50	59	54	49	47				47
6	73	60	51	45	71	59	51	45	57	50	44	55	49	44	54	48	44	42				42
7	67	54	46	40	66	54	46	40	52	45	40	51	44	39	49	43	39	37				37
8	63	50	41	36	61	49	41	36	48	41	35	46	40	35	45	39	35	33				33
9	59	46	38	32	57	45	37	32	44	37	32	43	36	32	42	36	32	30				30
10	55	42	34	29	54	42	34	29	41	34	29	40	33	29	39	33	29	27				27

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204621

CATALOG NUMBER: LD6B50D010TE EU6B30509030 6LBSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	189.3	3.8
10°-20°	539.5	10.9
20°-30°	812.5	16.4
30°-40°	966.8	19.5
40°-50°	965.0	19.5
50°-60°	784.8	15.8
60°-70°	482.8	9.7
70°-80°	187.0	3.8
80°-90°	30.0	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1541.3	31.1
0°-40°	2508.1	50.6
0°-60°	4257.9	85.9
0°-90°	4957.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4957.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1998	
5°	1992	189
15°	1915	540
25°	1768	813
35°	1548	967
45°	1254	965
55°	878	785
65°	485	483
75°	170	187
85°	24	30
90°	0	



TEST NUMBER: P204621

CATALOG NUMBER: LD6B50D010TE EU6B30509030 6LBSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1997.5
2.5°	2000.4
5°	1991.6
7.5°	1979.9
10°	1965.2
12.5°	1938.8
15°	1915.3
17.5°	1880.0
20°	1841.8
22.5°	1806.6
25°	1768.4
27.5°	1715.5
30°	1662.6
32.5°	1612.7
35°	1548.1
37.5°	1477.6
40°	1412.9
42.5°	1333.6
45°	1254.3
47.5°	1169.1
50°	1078.1
52.5°	984.1
55°	878.3
57.5°	775.5
60°	675.6
62.5°	578.7
65°	484.7
67.5°	396.6
70°	314.3
72.5°	237.9
75°	170.4
77.5°	111.6
80°	67.6
82.5°	41.1
85°	23.5
87.5°	11.8
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)