

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P205145

Luminaire Tested: **LD6B60D010TE EU6B60709024 6LBMLI1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205145
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6B60D010TE EU6B60709024 6LBMLI1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH SPECULAR CLEAR TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3861.3 lumens
Efficiency: N/A
Efficacy: 61.8 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 62.48
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205145

CATALOG NUMBER: LD6B60D010TE EU6B60709024 6LBMLI1

Luminous Intensity Polar Plot





TEST NUMBER: P205145

CATALOG NUMBER: LD6B60D010TE EU6B60709024 6LBMLI1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	114	111	109	106	111	109	107	105	105	103	101		101	100	98		98
2	108	103	100	96	106	102	98	95	99	96	93		96	93	91		93
3	103	97	92	88	101	95	91	87	93	89	86		90	87	85		88
4	98	91	85	81	96	89	84	81	87	83	80		85	82	79		83
5	93	85	79	75	91	84	79	75	82	78	74		81	77	73		79
6	89	80	74	70	87	79	74	70	78	73	69		76	72	69		75
7	84	75	69	65	83	75	69	65	73	68	65		72	68	64		71
8	80	71	65	61	79	70	65	61	69	64	61		68	64	60		67
9	77	67	61	57	75	67	61	57	66	61	57		65	60	57		64
10	73	64	58	54	72	63	58	54	62	57	54		62	57	54		61

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205145

CATALOG NUMBER: LD6B60D010TE EU6B60709024 6LBMLI1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	445.2	11.5
10°-20°	1108.3	28.7
20°-30°	1288.3	33.4
30°-40°	789.0	20.4
40°-50°	195.9	5.1
50°-60°	22.9	0.6
60°-70°	8.5	0.2
70°-80°	3.2	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2841.8	73.6
0°-40°	3630.8	94.0
0°-60°	3849.6	99.7
0°-90°	3861.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3861.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4832	
5°	4768	445
15°	3978	1108
25°	2851	1288
35°	1235	789
45°	217	196
55°	20	23
65°	10	9
75°	5	3
85°	0	0
90°	0	



TEST NUMBER: P205145

CATALOG NUMBER: LD6B60D010TE EU6B60709024 6LBMLI1

CANDELA DISTRIBUTION (FULL):

	0°
0°	4832.4
2.5°	4827.4
5°	4768.2
7.5°	4639.7
10°	4466.7
12.5°	4239.5
15°	3977.6
17.5°	3695.9
20°	3419.2
22.5°	3142.5
25°	2851.0
27.5°	2515.0
30°	2129.6
32.5°	1680.0
35°	1235.3
37.5°	869.6
40°	592.9
42.5°	370.6
45°	217.4
47.5°	123.5
50°	64.2
52.5°	29.6
55°	19.8
57.5°	14.8
60°	14.8
62.5°	9.9
65°	9.9
67.5°	4.9
70°	4.9
72.5°	4.9
75°	4.9
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)