

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P684796

Luminaire Tested: **LX6C120D010 EX61209030 6LBMLI**

Issue Date: 2/15/2022



**Test Information**

Test Method: LM-79-08  
Report Number: P684796  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)  
Test Lab: INNOVATION CENTER  
Issue Date: 2/15/2022  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LX6C120D010 EX61209030 6LBMLI  
Description: 6 INCH 12000 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 3000K, 90CRI LEDS  
AND 6LBM TRIM WITH LI FINISH  
Light Source: -  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 11086.0 lumens  
Efficiency: N/A  
Efficacy: 77.9 lumens/watt  
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 142.3  
Input Voltage (V):  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P684796

CATALOG NUMBER: LX6C120D010 EX61209030 6LBMLI

### Luminous Intensity Polar Plot





TEST NUMBER: P684796

CATALOG NUMBER: LX6C120D010 EX61209030 6LBMLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94			
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88			
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82			
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76			
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71			
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67			
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63			
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59			
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55			
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	760553
5°	753316
10°	713837
15°	648097
20°	572691
25°	495107
30°	387022
35°	237343
40°	121821
45°	48400
50°	15718
55°	5419
60°	4649
65°	3710
70°	2292
75°	3029
80°	0
85°	0



TEST NUMBER: P684796

CATALOG NUMBER: LX6C120D010 EX61209030 6LBMLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	1278.1	11.5
10°-20°	3181.9	28.7
20°-30°	3698.8	33.4
30°-40°	2265.1	20.4
40°-50°	562.5	5.1
50°-60°	65.7	0.6
60°-70°	24.6	0.2
70°-80°	9.4	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	8158.8	73.6
0°-40°	10423.9	94.0
0°-60°	11052.1	99.7
0°-90°	11086.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	11086.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	13874	
5°	13689	###
15°	11419	3182
25°	8185	3699
35°	3546	2265
45°	624	562
55°	57	66
65°	29	25
75°	14	9
85°	0	0
90°	0	



TEST NUMBER: P684796

CATALOG NUMBER: LX6C120D010 EX61209030 6LBMLI

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	13873.6
2.5°	13859.3
5°	13689.3
7.5°	13320.3
10°	12823.6
12.5°	12171.3
15°	11419.4
17.5°	10610.9
20°	9816.7
22.5°	9021.9
25°	8185.3
27.5°	7220.6
30°	6114.0
32.5°	4823.1
35°	3546.5
37.5°	2496.5
40°	1702.3
42.5°	1063.7
45°	624.3
47.5°	354.8
50°	184.3
52.5°	85.2
55°	56.7
57.5°	42.4
60°	42.4
62.5°	28.6
65°	28.6
67.5°	14.3
70°	14.3
72.5°	14.3
75°	14.3
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG







— 0°-180°







(END OF REPORT)