

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P684987

Luminaire Tested: **LX6C40D010 EX6409027 6LBMLI**

Issue Date: 2/15/2022



Test Information

Test Method: LM-79-08
Report Number: P684987
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)
Test Lab: INNOVATION CENTER
Issue Date: 2/15/2022
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LX6C40D010 EX6409027 6LBMLI
Description: 6 INCH 4000 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 2700K, 90CRI LEDS
AND 6LBM TRIM WITH LI FINISH
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 3540.0 lumens
Efficiency: N/A
Efficacy: 75.3 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 47
Input Voltage (V):
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P684987

CATALOG NUMBER: LX6C40D010 EX6409027 6LBMLI

Luminous Intensity Polar Plot





TEST NUMBER: P684987

CATALOG NUMBER: LX6C40D010 EX6409027 6LBMLI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94			
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88			
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82			
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76			
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71			
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67			
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63			
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59			
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55			
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	242859
5°	240551
10°	227946
15°	206954
20°	182873
25°	158096
30°	123582
35°	75790
40°	38901
45°	15451
50°	5015
55°	1730
60°	1480
65°	1180
70°	737
75°	974
80°	0
85°	0



TEST NUMBER: P684987

CATALOG NUMBER: LX6C40D010 EX6409027 6LBMLI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	408.1	11.5
10°-20°	1016.1	28.7
20°-30°	1181.1	33.4
30°-40°	723.3	20.4
40°-50°	179.6	5.1
50°-60°	21.0	0.6
60°-70°	7.8	0.2
70°-80°	3.0	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2605.3	73.6
0°-40°	3328.6	94.0
0°-60°	3529.1	99.7
0°-90°	3540.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3540.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	4430	
5°	4371	408
15°	3646	1016
25°	2614	1181
35°	1132	723
45°	199	180
55°	18	21
65°	9	8
75°	5	3
85°	0	0
90°	0	



TEST NUMBER: P684987

CATALOG NUMBER: LX6C40D010 EX6409027 6LBMLI

CANDELA DISTRIBUTION (FULL):

	0°
0°	4430.1
2.5°	4425.6
5°	4371.3
7.5°	4253.5
10°	4094.9
12.5°	3886.6
15°	3646.5
17.5°	3388.3
20°	3134.7
22.5°	2880.9
25°	2613.7
27.5°	2305.7
30°	1952.3
32.5°	1540.1
35°	1132.5
37.5°	797.2
40°	543.6
42.5°	339.7
45°	199.3
47.5°	113.3
50°	58.8
52.5°	27.2
55°	18.1
57.5°	13.5
60°	13.5
62.5°	9.1
65°	9.1
67.5°	4.6
70°	4.6
72.5°	4.6
75°	4.6
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG





— 0°-180°







(END OF REPORT)