

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P685209

Luminaire Tested: **LX6C75D010 EX6759050 6LBSLI**

Issue Date: 2/15/2022

**Test Information**

Test Method: LM-79-08  
Report Number: P685209  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205419)  
Test Lab: INNOVATION CENTER  
Issue Date: 2/15/2022  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LX6C75D010 EX6759050 6LBSLI  
Description: 6 INCH 7500 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 5000K, 90CRI LEDS  
AND 6LBS TRIM WITH LI FINISH  
Light Source: -  
Ballast/Driver: -


**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 9409.0 lumens  
Efficiency: N/A  
Efficacy: 115.4 lumens/watt  
Spacing Criteria (0/90/45): 0.91 / 0.91 / 1.04  
Luminous Opening: Circular (Dia: 0.5' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 81.5  
Input Voltage (V):  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT

TEST NUMBER: P685209

CATALOG NUMBER: LX6C75D010 EX6759050 6LBSLI

### Luminous Intensity Polar Plot





TEST NUMBER: P685209

CATALOG NUMBER: LX6C75D010 EX6759050 6LBSLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89			89
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77			77
3	95	86	79	74	93	85	78	73	82	76	72	79	75	71	77	73	70	68			68
4	88	78	70	64	86	77	69	64	74	68	63	72	67	62	70	65	62	60			60
5	82	71	63	57	80	70	62	57	67	61	56	66	60	55	64	59	55	53			53
6	76	64	56	51	74	63	56	51	62	55	50	60	54	50	59	53	49	47			47
7	71	59	51	46	70	58	51	45	57	50	45	55	49	45	54	49	45	43			43
8	67	54	47	41	65	54	46	41	52	46	41	51	45	41	50	45	41	39			39
9	63	50	43	38	61	50	43	38	49	42	38	48	42	37	47	41	37	36			36
10	59	47	40	35	58	46	39	35	45	39	35	45	39	34	44	38	34	33			33

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	325495
5°	321785
10°	305472
15°	281948
20°	257751
25°	233390
30°	212602
35°	196674
40°	183837
45°	171258
50°	156003
55°	136607
60°	113971
65°	89465
70°	62478
75°	33868
80°	6346
85°	0



TEST NUMBER: P685209

CATALOG NUMBER: LX6C75D010 EX6759050 6LBSLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	547.1	5.8
10°-20°	1392.9	14.8
20°-30°	1776.2	18.9
30°-40°	1842.0	19.6
40°-50°	1697.3	18.0
50°-60°	1276.7	13.6
60°-70°	689.1	7.3
70°-80°	184.9	2.0
80°-90°	2.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3716.2	39.5
0°-40°	5558.3	59.1
0°-60°	8532.2	90.7
0°-90°	9409.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	9409.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	5938	
5°	5848	547
15°	4968	1393
25°	3858	1776
35°	2939	1842
45°	2209	1697
55°	1429	1277
65°	690	689
75°	160	185
85°	0	3
90°	0	



TEST NUMBER: P685209

CATALOG NUMBER: LX6C75D010 EX6759050 6LBSLI

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	5937.5
2.5°	5917.6
5°	5847.5
7.5°	5717.6
10°	5487.6
12.5°	5257.9
15°	4967.9
17.5°	4698.2
20°	4418.2
22.5°	4128.4
25°	3858.5
27.5°	3598.6
30°	3358.6
32.5°	3138.7
35°	2938.8
37.5°	2748.8
40°	2568.9
42.5°	2379.1
45°	2209.0
47.5°	2019.2
50°	1829.2
52.5°	1629.4
55°	1429.3
57.5°	1229.5
60°	1039.5
62.5°	859.6
65°	689.7
67.5°	529.8
70°	389.8
72.5°	269.9
75°	159.9
77.5°	69.9
80°	20.1
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG







— 0°-180°







(END OF REPORT)